

Technical cross-section drawing of a wastewater treatment tank, labeled "ŘEZ B-B'". The drawing shows the internal structure, including a central vertical shaft with a pump assembly at the bottom labeled "ČERPADLO". The tank is surrounded by a concrete structure with a hatched pattern. Dimensions are provided in millimeters (mm) and meters (m). Key dimensions include a total width of 4000 mm and a total height of 2900 mm. The drawing also indicates various elevation levels: H_{hav} (average water level), H_{max} (maximum water level), and H_{min} (minimum water level). The bottom of the tank is at an elevation of -3.91 m, and the ground level is at -3.50 m. The drawing includes a red rectangle on the left side, likely indicating a specific area of interest or a structural detail.

čerpané množství: 4,0 - 5,0 l/s

- 1 KRUHOVÁ ŠACHTA PU 2500/2900 mm
- 3 VÍKO PU 2500 - TŘI OTVORY
- 3 POKLOP S RÁMEM prům. 600 mm
- 4 LOŽE ZE ŠTĚRKODRTI tl. 100-150 mm
- 5 ZÁSYP HUTNĚNÝ
- 6 ÚTES PVC 200 - ČERPAČÍ JÍMKA

Technical schematic of a vacuum furnace. The diagram shows a cross-section of the furnace chamber, which is a large circle containing an octagonal inner chamber. Inside the octagonal chamber, there are two circular components, likely heaters, and a central vertical structure. The furnace is surrounded by a thick, light-gray insulation layer. Labels with arrows point to specific parts: 'ELEKTRO' points to a small component on the top left of the insulation layer; 'NÁTOK' points to a red rectangular area on the left side of the insulation layer, indicating an inlet; 'VÝTLAK' points to a horizontal pipe on the right side of the insulation layer, indicating an outlet.

D	H1	H 2	H 3	H min	H max	H hav
m	m	m	m	m	m	m
2,5	2,0	2,25	2,9	0,2	0,6	2,0

VÝTLAK: PE 100RC, SDR 11, De 75



ODPOV. PROJEKTANT:	VYPRACOVAL:	SPOLUPRÁCE:	PROJEKTOVÁ KANCELÁŘ Petr Datel <i>Tyršova 1902, 256 01 Benešov</i> tel.: 603 466 547	
ING. DATEL	P. DATEL			
MÍSTO:	KRAJ:	OBCENÍ (MĚSTSKÝ) ÚŘAD:		
RABYNĚ	STŘEDOČESKÝ	RABYNĚ	FORMÁT:	2 x A4
INVESTOR: Obec Rabyně, Blaženice 16, 257 44 Netvořice			STUPEŇ:	RDS
SPLAŠKOVÁ KANALIZACE RABYNĚ - ROZŠÍŘENÍ			ZAK.Č.	35-2018
			DATUM:	07/2024
			MĚŘITKO:	1 : 25
OBSAH:			Č.PŘÍLOHY:	
ČERPACÍ STANICE			2.9.	