

Množství															
Po	KKS	Sig	Popis	Signál	Oblast	Rozsah	Jed	Vyr	Dod	Vyr	Typ	Rozsah	Jed	Nastaveno	Jed
1	00GBK50CFO01	XG50	F Demi-Vo DodNap TopVo	4 - 20 mA	DALKTOP	0	19 kg/s	Prib Clo	BFS	ABB H&B	ASK 800				
2	00GMA40CFO01	XG50	F OdpadVo Kan	4 - 20 mA	KOND	0	250 m3/h	UZ Snimc	Danfos	ABB	SONO 3000				
3	00NAA80CFO01	XG50	F Par RezTopOhr	4 - 20 mA	VO PAR	0	42 kg/s	Prib Clo+Vyrovnado	BFS	ABB H&B	ASK 800	0	2,5 bar	0	750 mbar
4	00NAA81CFO01	XG50	F Par za NajRedukStan	4 - 20 mA	VO PAR	0	30 kg/s	Prib Clo+Vyrovnado	BFS	ABB H&B	ASK 800	0	2,5 bar	0	700 mbar
5	00NAB85CFO01	XG50	F Kond za RezTopOhr	4 - 20 mA	KOND	0	45 kg/s	Prib Clo	BFS	ABB H&B	ASK 800	0	2,5 bar	0	700 mbar
6	00NDB07CFO01	XG11	F TopVo - rozsah A	Kontakt 48 V	DALKTOP										
7	00NDB07CFO01	XG12	F TopVo - smer spotrebic	Kontakt 48 V	DALKTOP										
8	00NDB07CFO01A	XG50	F TopVo VyrovoPotr	4 - 20 mA	DALKTOP	0	100 m3/h	UZ Snimc	Danfos	ABB	SONO 3000	0	60 kg/s		
9	00NDB07CFO01B	XG50	F TopVo VyrovoPatr	4 - 20 mA	DALKTOP	0	30 m3/h								
10	00NDB10CFO01	XG50	F TopVo Sit VratTk	4 - 20 mA	DALKTOP	0	4500 m3/h	UZ Snimc	Danfos	ABB	SONO 3000	0	1250 kg/s		
11	00NDB27CFO01	XG50	F TopVo VratTk TopVokot	4 - 20 mA	DALKTOP	0	3000 m3/h	UZ Snimc	Danfos	ABB	SONO 3000	0	830 kg/s		
12	00PAR10CFO01	XG50	F PrumysVo	4 - 20 mA	KOND	0	260 m3/h	UZ Snimc	Danfos	ABB	SONO 3000	0	85 kg/s		
13	00PAR40CFO01	XG50	F DodNap PrumysVo	4 - 20 mA	KOND	0	250 m3/h	UZ Snimc	Danfos	ABB	SONO 3000	0	70 kg/s		
14	00PBR10CFO01	XG50	F Chlavo	4 - 20 mA	CHLADVO	0	100 m3/h	UZ Snimc	Danfos	ABB	SONO 3000	0	100 m3/h		
15	00QEB20CFO01	XG50	F PracVzd Skoda ZavdSit	4 - 20 mA	KOND	0	0,45 m3/s	Prib Clo	BFS	ABB H&B	ASK 800	0	400 mbar	0	200 mbar
16	00QFB81CFO01	XG50	F SysRidVzd	4 - 20 mA	K80	0	0,75 kg/s	Prib Clo	BFS	ABB H&B	ASK 800	0	400 mbar	0	100 mbar
17	00QFB91CFO01	XG50	F SysRidVzd	4 - 20 mA	K90	0	0,75 kg/s	Prib Clo	BFS	ABB H&B	ASK 800	0	400 mbar	0	100 mbar
18	08LAS10CF301	XG11	F NouzCerpNapVo	Kontakt 48 V	VO PAR			Hlidi Pruk	IFM	ABB	VS0200 VR31				
19	08LBG10CFO01	XG50	F PomPar NadrNapVo 80/90	4 - 20 mA	VO PAR	0	14 kg/s	Prib Clo+Vyrovnado	BFS	ABB H&B	ASK 800	0	2,5 bar	0	500 mbar
20	08NDB10CFO01	XG50	F TopVo z RezTopOhr	4 - 20 mA	DALKTOP	0	1500 m3/h	UZ Snimc	Danfos	ABB	SONO 3000	0	420 kg/s		
21	70HAA10CFO01	XG50	F Vo VHV Vst	4 - 20 mA	K70	0	10 kg/s	Sonda MerNap TI	Systec	ABB H&B	ASK 800	0	60 mbar	0	21,12 mbar
22	70HHF01CFO01	XG50	F TopOI	4 - 20 mA	K70	0	5 t/h	Kruh Pist Citac	Siemens		7MV1110-1AA20				
23	70HHF01CFO01	XZ21	F TopOI	Kontakt 48 V	K70	0	5000 kg/s	Kruh Pist Citac	Siemens	ABB					
24	70HHG01CFO01	XG50	F ZemPly	4 - 20 mA	K70	0	5500 Nm3/h	Prib Clo	BFS	ABB H&B	ASK 800	0	400 mbar	0	300 mbar
25	70HHG01CFO02	XG50	F ZemPly	4 - 20 mA	K70	0	5500 Nm3/h		BFS	ABB H&B	ASK 800	0	400 mbar	0	400 mbar
26	70HLA02CFO01	XG50	F SpalVzd	4 - 20 mA	K70	0	25 kg/s	Sonda MerNap TI	UNIMES	ABB	ASK 800	0	10 mbar	0	6,503 mbar
27	70HLA02CFO02	XG50	F SpalVzd	4 - 20 mA	K70	0	25 kg/s	Sonda MerNap TI	UNIMES	EVT H&B	ASK 800	0	10 mbar	0	6,503 mbar
28	70HNF01CFO01	XG50	F Reci Spln	4 - 20 mA	K70	0	3 kg/s	Sonda MerNap TI	UNIMES		ASK 800	0	10 mbar	0	6,987 mbar
29	70HNF01CFO02	XG50	F Reci Spln	4 - 20 mA	K70	0	3 kg/s		UNIMES	EVT H&B	ASA 800	0	10 mbar	0	6,987 mbar
30	70LAB20CFO01	XG50	F NapVo	4 - 20 mA	K70	0	25 kg/s		BFS	ABB H&B	ASK 800	0	400 mbar	0	350 mbar
31	70LAE02CFO01	XG50	F VstrVo VstrChlac 1	4 - 20 mA	K70	0	4 kg/s	Norm Clo	BFS	ABB H&B	ASK 800	0	2,5 bar	0	500 mbar
32	70LAE03CFO01	XG50	F VstrVo VstrChlac 2	4 - 20 mA	K70	0	4 kg/s	Norm Clo	BFS	ABB H&B	ASK 800	0	2,5 bar	0	500 mbar
33	70LBA10CFO01	XG50	F OP	4 - 20 mA	K70	0	20 kg/s	Norm Clo	BFS	ABB H&B	ASK 800	0	2,5 bar	0	1200 mbar
34	70LBA10CFO02	XG50	F NajPar	4 - 20 mA	K70	0	10 kg/s	Norm Clo	BFS	ABB H&B	ASK 800	0	2,5 bar	0	1200 mbar
35	80GHC06CFO01	XG50	F DemiVo Chlavo ExpdNadr	4 - 20 mA	VO PAR	0	1,5 kg/s	Vodomer DN32/PN16	KENT	ABB KENT	FU1-11 220V/50Hz	0	1,5 kg/s	0	1,5 kg/s
36	80HHQ01CFO01	XG50	F Vzd za Ventr TridicPop	4 - 20 mA	K80	0	2 kg/s	VentrTr	EVT	ABB H&B	ASK 800	0	60 mbar	0	10 mbar
37	80HHS02CFO01	XG50	F FluidVzd TridicPop	4 - 20 mA	K80	0	0,05 kg/s	Norm Clo 1-Dil	EVT	ABB H&B	ASK 800	0	60 mbar	0	50 mbar
38	80HHS21CFO01	XG50	F FluidVzd1 PopZpPropst	4 - 20 mA	K80	0	0,3 kg/s	Norm Clo 1-Dil	EVT	ABB H&B	ASK 800	0	60 mbar	0	20 mbar
39	80HHS22CFO01	XG50	F FluidVzd2 PopZpPropst	4 - 20 mA	K80	0	0,3 kg/s	Norm Clo 1-Dil	EVT	ABB H&B	ASK 800	0	60 mbar	0	50 mbar
40	80HHS23CFO01	XG50	F FluidVzd3 PopZpPropst	4 - 20 mA	K80	0	0,3 kg/s	Norm Clo 1-Dil	EVT	ABB H&B	ASK 800	0	60 mbar	0	20 mbar
41	80HUG21CFO01	XG50	F Ply NajHor 1	4 - 20 mA	K80	0	0,4 kg/s	Prib Clo	BFS	ABB H&B	ASK 800	0	400 mbar	0	300 mbar
42	80HUG22CFO01	XG50	F Ply NajHor 2	4 - 20 mA	K80	0	0,4 kg/s	Prib Clo	BFS	ABB H&B	ASK 800	0	400 mbar	0	300 mbar
43	80HUG23CFO01	XG50	F Ply NajHor 3	4 - 20 mA	K80	0	0,4 kg/s	Prib Clo	BFS	ABB H&B	ASK 800	0	400 mbar	0	300 mbar

44	80HJL11CF001	XQ50	F SekVzd Spod	4 - 20 mA	K8u	0	10	kg/s *	VenturTr	EVT	EVT	H&B	ASK 800	0	60	mbar	0	15	mbar
45	80HJL21CF001	XQ50	F SekVzd NajHor 1	4 - 20 mA	K80	0	7	kg/s	VenturTr	EVT	EVT	H&B	ASK 800	0	60	mbar	0	15	mbar
46	80HJL22CF001	XQ50	F SekVzd NajHor 2	4 - 20 mA	K80	0	7	kg/s	VenturTr	EVT	EVT	H&B	ASK 800	0	60	mbar	0	15	mbar
47	80HJL23CF001	XQ50	F SekVzd NajHor 3	4 - 20 mA	K80	0	7	kg/s	VenturTr	EVT	EVT	H&B	ASK 800	0	60	mbar	0	15	mbar
48	80HNF11CF001	XQ50	F Spin Recirk k PrimVzd	4 - 20 mA	K80	0	5	kg/s	VenturTr	EVT	EVT	H&B	ASK 800	0	60	mbar	0	50	mbar
49	80HNF12CF001	XQ50	F Spin Recirk k TridicPo	4 - 20 mA	K80	0	2	kg/s	VenturTr	EVT	EVT	H&B	ASK 800	0	60	mbar	0	10	mbar
50	80LAB30CF001	XQ50	F NapVo Kot 80	4 - 20 mA	VO PAR	0	56	kg/s	Norm Clo	BFS	ABB	H&B	ASK 800	0	2,5	bar	0	500	mbar
51	80LAB30CF002	XQ50	F NapVo Kot 80	4 - 20 mA	VO PAR	0	12	kg/s		BFS	ABB	H&B	ASK 800	0	60	mbar	0	22,96	mbar
52	80LAC11CF011	XQ50	F za CerpNapVo 80/11	4 - 20 mA	VO PAR	0	56	kg/s	Norm Clo	BFS	ABB	H&B	ASK 800	0	2,5	bar	0	500	mbar
53	80LAC12CF012	XQ50	F za CerpNapVo 80/12	4 - 20 mA	VO PAR	0	56	kg/s	Norm Clo	BFS	ABB	H&B	ASK 800	0	2,5	bar	0	500	mbar
54	80LAE21CF001	XQ50	F VstrivVo	4 - 20 mA	K80	0	3,5	kg/s	Norm Clo	BFS	ABB	H&B	ASK 800	0	2,5	bar	0	900	mbar
55	80LAE31CF001	XQ50	F VstrivVo	4 - 20 mA	K80	0	2,5	kg/s	Norm Clo	BFS	ABB	H&B	ASK 800	0	2,5	bar	0	700	mbar
56	80LAE45CF001	XQ50	F VstrivVo CerpNapVo 80	4 - 20 mA	VO PAR	0	14	kg/s	Norm Clo	BFS	ABB	H&B	ASK 800	0	2,5	bar	0	700	mbar
57	80LBA10CF001	XG50	F OP	4 - 20 mA	VO PAR	0	56	kg/s	Norm Clo	BFS	ABB	H&B	ASK 800	0	2,5	bar	0	2000	mbar
58	80LBA10CF002	XG50	F OP	4 - 20 mA	VO PAR	0	12	kg/s		BFS	ABB	H&B	ASK 800	0	400	mbar	0	91,84	mbar
59	80LBA20CF001	XG50	F OP pred Turb 80	4 - 20 mA	VO PAR	0	50	kg/s	Norm Clo	BFS	ABB	H&B	ASK 800	0	2,5	bar	0	2000	mbar
60	80LBH10CF001	XQ50	F NajPar Kot 80	4 - 20 mA	VO PAR	0	23	kg/s	Norm Clo	BFS	ABB	H&B	ASK 800	0	16	bar	0	5500	mbar
61	80LBH10CF002	XQ50	F NajPar Kot 80	4 - 20 mA	VO PAR	0	23	kg/s		BFS	ABB	H&B	ASK 800	0	16	bar	0	5500	mbar
62	80LCA20CF001	XQ50	F HIKond	4 - 20 mA	KOND	0	45	kg/s	Prib Clo	BFS	ABB	H&B	ASK 800	0	16	bar	0	5500	mbar
63	80LCA20CF002	XQ50	F HIKond	4 - 20 mA	KOND	0	45	kg/s	Prib Clo	BFS	ABB	H&B	ASK 800	0	2,5	bar	0	500	mbar
64	80LCM30CF001	XQ50	F za CerpProvKond 80	4 - 20 mA	KOND	0	11	kg/s	Prib Clo	BFS	ABB	H&B	ASK 800	0	400	mbar	0	300	mbar
65	80NAB20CF001	XQ50	F TopKond za TopOhr B180	4 - 20 mA	KOND	0	40	kg/s	Prib Clo	BFS	ABB	H&B	ASK 800	0	2,5	bar	0	500	mbar
66	80NDB10CF001	XQ50	F TopVo z TopOhr 80	4 - 20 mA	DALKTOP	0	3500	m3/h	UZ Snimc	Dantos	ABB	H&B	SONO 3000	0	975	kg/s			
67	80PAB20CF001	XQ50	F HIChavo pred KondB180	4 - 20 mA	CHLADVO	0	1800	kg/s	Sonda MerNapTI	Systec	ABB	H&B	ASK 800	0	400	mbar	0	91,41	mbar
68	80PGB40CF001	XQ50	F MezicChavo za Cerp	4 - 20 mA	CHLADVO	0	195	kg/s	Prib Clo	BFS	ABB	H&B	ASK 800	0	400	mbar	0	300	mbar
69	80PGB70CF021	XQ50	F MezicChavo	4 - 20 mA	K80	0	2,3	kg/s	Prib Clo	BFS	ABB	H&B	ASK 800	0	400	mbar	0	150	mbar
70	80PGB70CF023	XQ50	F MezicChavo	4 - 20 mA	K80	0	4,5	kg/s	Prib Clo	BFS	ABB	H&B	ASK 800	0	2,5	bar	0	500	mbar
71	80PGB75CF021	XQ50	F Sys MezicChavo	4 - 20 mA	K80	0	2,3	kg/s	Prib Clo	BFS	ABB	H&B	ASK 800	0	400	mbar	0	150	mbar
72	80PGB75CF023	XQ50	F Sys MezicChavo	4 - 20 mA	K80	0	4,5	kg/s	Prib Clo	BFS	ABB	H&B	ASK 800	0	2,5	bar	0	700	mbar
73	80PGM10CF001	XQ50	F MezicChavo pred Genchl	4 - 20 mA	CHLADVO	0	84	kg/s	Prib Clo	BFS	ABB	H&B	ASK 800	0	400	mbar	0	300	mbar
74	80QEEB01CF001	XQ50	F DopVzd	4 - 20 mA	K80	0	1,6	kg/s	Prib Clo	BFS	ABB	H&B	ASK 800	0	400	mbar	0	300	mbar
75	90GHC05CF001	XQ50	F DemivVo ChivOExpNadr	4 - 20 mA	VO PAR	0	1,5	kg/s	Vodomer DN32/PN16	KENT	ABB	KENT	FIU-11 220V/50Hz	0	1,5	kg/s	0	1,5	kg/s
76	90HHQ01CF001	XQ50	F Vzd za Ventr TridicPop	4 - 20 mA	K90	0	2	kg/s	VenturTr	EVT	EVT	H&B	ASK 800	0	60	mbar	0	10	mbar
77	90HHS02CF001	XQ50	F FluidVzd TridicPop	4 - 20 mA	K90	0	0,05	kg/s	Norm Clo 1-Dil	EVT	EVT	H&B	ASK 800	0	60	mbar	0	50	mbar
78	90HHS21CF001	XQ50	F FluidVzd1 PopzPrPropst		K90	0	0,3	kg/s	Norm Clo 1-Dil	EVT	EVT	H&B	ASK 800	0	60	mbar	0	20	mbar
79	90HHS22CF001	XQ50	F FluidVzd2 PopzPrPropst		K90	0	0,3	kg/s	Norm Clo 1-Dil	EVT	EVT	H&B	ASK 800	0	60	mbar	0	50	mbar
80	90HHS23CF001	XQ50	F FluidVzd3 PopzPrPropst		K90	0	0,3	kg/s	Norm Clo 1-Dil	EVT	EVT	H&B	ASK 800	0	60	mbar	0	20	mbar
81	90HJG21CF001	XQ50	F Ply NajHor 1	4 - 20 mA	K90	0	0,4	kg/s	Prib Clo	BFS	ABB	H&B	ASK 800	0	400	mbar	0	300	mbar
82	90HJG22CF001	XQ50	F Ply NajHor 2	4 - 20 mA	K90	0	0,4	kg/s	Prib Clo	BFS	ABB	H&B	ASK 800	0	400	mbar	0	300	mbar
83	90HJG23CF001	XQ50	F Ply NajHor 3	4 - 20 mA	K90	0	0,4	kg/s	Prib Clo	BFS	ABB	H&B	ASK 800	0	400	mbar	0	300	mbar
84	90HJL11CF001	XQ50	F SekVzd Spod	4 - 20 mA	K90	0	10	kg/s	VenturTr	EVT	EVT	H&B	ASK 800	0	60	mbar	0	15	mbar
85	90HJL12CF001	XQ50	F SekVzd NajHor 1	4 - 20 mA	K90	0	7	kg/s	VenturTr	EVT	EVT	H&B	ASK 800	0	60	mbar	0	15	mbar
86	90HJL22CF001	XQ50	F SekVzd NajHor 2	4 - 20 mA	K90	0	7	kg/s	VenturTr	EVT	EVT	H&B	ASK 800	0	60	mbar	0	15	mbar
87	90HJL23CF001	XQ50	F SekVzd NajHor 3	4 - 20 mA	K90	0	7	kg/s	VenturTr	EVT	EVT	H&B	ASK 800	0	60	mbar	0	15	mbar
88	90HNF11CF001	XQ50	F Spin Recirk k PrimVzd	4 - 20 mA	K90	0	5	kg/s	VenturTr	EVT	EVT	H&B	ASK 800	0	60	mbar	0	50	mbar
89	90HNF12CF001	XQ50	F Spin Recirk k TridicPo	4 - 20 mA	K90	0	2	kg/s	VenturTr	EVT	EVT	H&B	ASK 800	0	60	mbar	0	10	mbar
90	90LAB30CF001	XQ50	F NapVo Kot 90	4 - 20 mA	VO PAR	0	56	kg/s	Norm Clo	BFS	ABB	H&B	ASK 800	0	2,5	bar	0	500	mbar
91	90LAB30CF002	XQ50	F NapVo Kot 90	4 - 20 mA	VO PAR	0	12	kg/s		BFS	ABB	H&B	ASK 800	0	60	mbar	0	22,96	mbar

92	90LAC11CF011	XQ50	F NapVoCerp 90M1	4 - 20 mA	VC PAR	0	56	kg/s*	Norm Clo	BFS	ABB	H&B	ASK 800	0	2,5	bar	0	500	mbar
93	90LAC12CF012	XQ50	F NapVoCerp 90M12	4 - 20 mA	VO PAR	0	56	kg/s	Norm Clo	BFS		H&B	ASK 800	0	2,5	bar	0	500	mbar
94	90LAE21CF001	XQ50	F VstrVo	4 - 20 mA	K90	0	3,5	kg/s	Norm Clo	BFS	ABB	H&B	ASK 800	0	2,5	bar	0	900	mbar
95	90LAE31CF001	XQ50	F VstrVo	4 - 20 mA	K90	0	2,5	kg/s	Norm Clo	BFS	ABB	H&B	ASK 800	0	2,5	bar	0	700	mbar
96	90LAE45CF001	XQ50	F VstrVo NapVoCerp B190	4 - 20 mA	VO PAR	0	14	kg/s	Norm Clo	BFS	ABB	H&B	ASK 800	0	2,5	bar	0	700	mbar
97	90LBA10CF001	XQ50	F OP K90	4 - 20 mA	VO PAR	0	56	kg/s	Norm Clo	BFS	ABB	H&B	ASK 800	0	2,5	bar	0	2000	mbar
98	90LBA10CF002	XQ50	F OP K90	4 - 20 mA	VO PAR	0	12	kg/s		BFS	ABB	H&B	ASK 800	0	400	mbar	0	91,84	mbar
99	90LBA20CF001	XQ50	F OP pred Turb 90	4 - 20 mA	VO PAR	0	50	kg/s	Norm Clo	BFS	ABB	H&B	ASK 800	0	2,5	bar	0	2000	mbar
100	90LBH10CF001	XQ50	F NapPark90	4 - 20 mA	VO PAR	0	23	kg/s	Norm Clo	BFS	ABB	H&B	ASK 800	0	16	bar	0	5500	mbar
101	90LBH10CF002	XQ50	F NapPark90	4 - 20 mA	VO PAR	0	23	kg/s		BFS	ABB	H&B	ASK 800	0	16	bar	0	5500	mbar
102	90LCA20CF001	XQ50	F Hlkond	4 - 20 mA	KOND	0	45	kg/s	Prith Clo	BFS	ABB	H&B	ASK 800	0	2,5	bar	0	500	mbar
103	90LCA20CF002	XQ50	F Hlkond	4 - 20 mA	KOND	0	45	kg/s		BFS	ABB	H&B	ASK 800	0	2,5	bar	0	500	mbar
104	90LCM30CF001	XQ50	F za ProvKondCerp B1 90	4 - 20 mA	KOND	0	11	kg/s	Prith Clo	BFS	ABB	H&B	ASK 800	0	400	mbar	0	300	mbar
105	90NAB20CF001	XQ50	F TopKond za TopOhr B190	4 - 20 mA	KOND	0	40	kg/s	Prith Clo	BFS	ABB	H&B	ASK 800	0	2,5	bar	0	500	mbar
106	90NDB10CF001	XQ50	F TopVo z TopOhr 90	4 - 20 mA	DALKTOP	0	3500	m3/h	UZ Snlmc		ABB		SONO 3000	0	975	kg/s			
107	90PAB20CF001	XQ50	F HIChlaVo pred KondB190	4 - 20 mA	CHLADVO	0	1800	kg/s	Sonda MerNapTI	Systec	ABB	H&B	ASK 800	0	400	mbar	0	91,41	mbar
108	90PGB40CF001	XQ50	F MeziChlaVo za VoCerp	4 - 20 mA	CHLADVO	0	195	kg/s	Prith Clo	BFS	ABB	H&B	ASK 800	0	400	mbar	0	300	mbar
109	90PGB70CF021	XQ50	F MeziChlaVo	4 - 20 mA	K90	0	2,3	kg/s	Prith Clo	BFS	ABB	H&B	ASK 800	0	400	mbar	0	150	mbar
110	90PGB70CF023	XQ50	F MeziChlaVo	4 - 20 mA	K90	0	4,5	kg/s	Prith Clo	BFS	ABB	H&B	ASK 800	0	2,5	bar	0	500	mbar
111	90PGB75CF021	XQ50	F Sys MeziChlaVo	4 - 20 mA	K90	0	2,3	kg/s	Prith Clo	BFS	ABB	H&B	ASK 800	0	400	mbar	0	150	mbar
112	90PGB75CF023	XQ50	F Sys MeziChlaVo	4 - 20 mA	K90	0	4,5	kg/s	Prith Clo	BFS	ABB	H&B	ASK 800	0	2,5	bar	0	700	mbar
113	90PGM10CF001	XQ50	F MChV pred GenChlaB190	4 - 20 mA	CHLADVO	0	84	kg/s	Prith Clo	BFS	ABB	H&B	ASK 800	0	400	mbar	0	300	mbar
114	90QEB01CF001	XQ50	F DopVzrd	4 - 20 mA	K90	0	1,6	kg/s	Prith Clo	BFS	ABB	H&B	ASK 800	0	400	mbar	0	300	mbar
115	Q3NDA01CF001	XQ50	F TopVo Stian HN1M1	4 - 20 mA	DALKTOP	0	400	m3/h											
116	Q3NDA02CF001	XQ50	F TopVo Stian HN1M2	4 - 20 mA	DALKTOP	0	1200	m3/h											
117	Q3NDA03CF001	XQ50	F TopVo Stian HN1M3	4 - 20 mA	DALKTOP	0	150	m3/h											
118	Q3NDA04CF001	XQ50	F TopVo Stian HN1M4	4 - 20 mA	DALKTOP	0	30	m3/h											
119	Q3NDA11CF001	XQ50	F TopVo Stian HN1Z1	4 - 20 mA	DALKTOP	0	1500	m3/h											
120	Q3NDA12CF001	XQ50	F TopVo Stian HN1Z2	4 - 20 mA	DALKTOP	0	2200	m3/h											

