

Spaliny a prach															Spaliny			
Po	KKS	Slg	Popis	Slg	Oblast	Rozsah	Jedn.	Popis měření	Výr	Typ	Popis měření	Výr	Typ	Rozsah	Jedn.			
1	40HBK04CQ010	XG11	K40 PortMereni Emisi	Kontakt 48 \ K90														
2	40HBK04CQ011	XQ50	Tuhc Spin K40	4 - 20 mA	K90	0	100 mg/Nm3											
3	40HBK04CQ012	XQ50	SO2 Spin K40	4 - 20 mA	K90	0	3400 mg/Nm3											
4	40HBK04CQ013	XQ50	CO Spin K40	4 - 20 mA	K90	0	350 mg/Nm3											
5	40HBK04CQ014	XQ50	NO Spin K40	4 - 20 mA	K90	0	900 mg/Nm3											
6	40NDB01CG001	XQ50	G Uzklap TopVo ke K40	4 - 20 mA	DALKTOP	0	100 %											
7	50HBK04CQ010	XG11	K50 PortMereni Emisi	Kontakt 48 \ K90														
8	50HBK04CQ011	XQ50	Tuhc Spin K50	4 - 20 mA	K90	0	100 mg/Nm3											
9	50HBK04CQ012	XQ50	SO2 Spin K50	4 - 20 mA	K90	0	3400 mg/Nm3											
10	50HBK04CQ013	XQ50	CO Spin K50	4 - 20 mA	K90	0	350 mg/Nm3											
11	50HBK04CQ014	XQ50	NO Spin K50	4 - 20 mA	QIC	0	900 mg/Nm3											
12	50NDB10CG001	XQ50	G UzKI TopVo ZpTok k K50	4 - 20 mA	DALKTOP	0	100 %											
13	60HBK04CQ010	XG11	K60 PortMereni Emisi	Kontakt 48 \ K90		0												
14	60HBK04CQ011	XQ50	Tuhc Spin K60	4 - 20 mA	K90	0	100 mg/Nm3											
15	60HBK04CQ012	XQ50	SO2 Spin K60	4 - 20 mA	K90	0	3400 mg/Nm3											
16	60HBK04CQ013	XQ50	CO Spin K60	4 - 20 mA	K90	0	350 mg/Nm3											
17	60HBK04CQ014	XQ50	NO Spin K60	4 - 20 mA	K90	0	900 mg/Nm3											
18	70HBK04CQ010	XQ50	CO Spin K70	4 - 20 mA	K70	0	250 mg/Nm3	Spin-Upr. Odbe Typ 1	EGA		CO-Mereni	H&B	URAS 14	0	250 mg/Nm3			
19	70HBK04CQ011	XQ50	NO Spin K70	4 - 20 mA	K70	0	500 mg/Nm3	Spin-Upr. Odbe Typ 1	EGA		NO-Mereni	H&B	URAS 14	0	500 mg/Nm3			
20	70HBK04CQ012	XQ50	O2 Spin K70	4 - 20 mA	K70	0	25 %	Spin-Upr. Odbe Typ 1	EGA		O2-Mereni	H&B	URAS 14	0	25 %			
21	70HBK04CQ013	XQ50	Tuhc Spin K70	4 - 20 mA	K70	0	25 mg/Nm3	Spin-Upr. Odbe Typ 2	EGA		Prach-Mereni	Durag	DR300-40	0	25 mg/Nm3			
22	70QUA10CQ003	XQ50	O2 NapVo	4 - 20 mA	K70	0	199 ug/l	PA (EGA)O2Snimac	KENT 9435-300		CO-Mereni	KENT	9435-000	0	50 ug/l			
23	80HFG10CQ001	XQ50	CO-Zasobuhl	4 - 20 mA	K80	0	1000 mg/m3	Spin-Upr. Odbe Typ 1	EGA		CO-Mereni	H&B	URAS 14	0	1000 ppm			
24	80HNA03CQ001	XQ50	O2 Spin pred LUVO	4 - 20 mA	K80	0	25 %	Spin-Upr. Odbe Typ 1	EGA		O2-Mereni	H&B	URAS 14	0	25 %			
25	80HNA03CQ002	XQ50	CO Spin pred LUVO	4 - 20 mA	K80	0	300 mg/m3	Spin-Upr. Odbe Typ 1	EGA		CO-Mereni	H&B	URAS 14	0	300 mg/m3			
26	80HNA06CQ001	XQ50	Prach Spin za KV	4 - 20 mA	K80	0	125 mg/Nm3	Spin-Upr. Odbe Typ 2	EGA		Prach-Mereni	Durag	DR300-40	0	125 mg/Nm3			
27	80HNA06CQ002	XQ50	O2 Spin za KV	4 - 20 mA	K80	0	25 %	Spin-Upr. Odbe Typ 1	EGA		O2-Mereni	H&B	URAS 14	0	25 %			
28	80HNA06CQ003	XQ50	SO2 Spin za KV	4 - 20 mA	K80	0	1250 mg/Nm3	Spin-Upr. Odbe Typ 1	EGA		SO2-Mereni	H&B	URAS 14	0	1250 mg/Nm3			
29	80HNA06CQ004	XQ50	CO Spin za KV	4 - 20 mA	K80	0	600 mg/Nm3	Spin-Upr. Odbe Typ 1	EGA		CO-Mereni	EGA	URAS 14	0	600 mg/Nm3			
30	80HNA06CQ005	XQ50	NO Spin za KV	4 - 20 mA	K80	0	1000 mg/Nm3	Spin-Upr. Odbe Typ 1	EGA		NO-Mereni	H&B	URAS 14	0	1000 mg/Nm3			
31	80QUA20CQ003	XQ50	O2 NapVo	4 - 20 mA	VO PAR	0	199 ug/l	PA (EGA)O2Snimac	KENT 9435-300		CO-Mereni	KENT	9435-000	0	199 ug/l			
32	90HFG10CQ001	XQ50	Q (CO) Zasobuhl 1	4 - 20 mA	K90	0	1000 mg/m3	Spin-Upr. Odbe Typ 1	EGA		CO-Mereni	H&B	URAS 14	0	1000 ppm			
33	90HNA03CQ001	XQ50	O2 Spin pred LUVO	4 - 20 mA	K90	0	25 %	Spin-Upr. Odbe Typ 1	EGA		O2-Mereni	H&B	URAS 14	0	25 %			
34	90HNA03CQ002	XQ50	CO Spin pred LUVO	4 - 20 mA	K90	0	300 mg/m3	Spin-Upr. Odbe Typ 1	EGA		CO-Mereni	H&B	URAS 14	0	300 mg/m3			
35	90HNA06CQ001	XQ50	Prach Spin za KV	4 - 20 mA	K90	0	125 mg/Nm3	Spin-Upr. Odbe Typ 2	EGA		Prach-Mereni	Durag	DR300-40	0	125 mg/m3			
36	90HNA06CQ002	XQ50	O2 Spin za KV	4 - 20 mA	K90	0	25 %	Spin-Upr. Odbe Typ 1	EGA		O2-Mereni	H&B	URAS 14	0	25 %			
37	90HNA06CQ003	XQ50	SO2 Spin za KV	4 - 20 mA	K90	0	1250 mg/Nm3	Spin-Upr. Odbe Typ 1	EGA		SO2-Mereni	H&B	URAS 14	0	1250 mg/m3			
38	90HNA06CQ004	XQ50	CO Spin za KV	4 - 20 mA	K90	0	600 mg/Nm3	Spin-Upr. Odbe Typ 1	EGA		CO-Mereni	H&B	URAS 14	0	600 mg/m3			
39	90HNA06CQ005	XQ50	NO Spin za KV	4 - 20 mA	K90	0	1000 mg/Nm3	Spin-Upr. Odbe Typ 1	EGA		NO-Mereni	H&B	URAS 14	0	1000 mg/m3			
40	90QUA20CQ003	XQ50	O2 OdbeZkVizik NapVo K90	4 - 20 mA	VO PAR	0	199 ug/l	PA (EGA)O2Snimac	KENT 9435-300		CO-Mereni	KENT	9435-000	0	199 ug/l			

