

Tepelná a tlakové difference														
Po	KKS	Sig	Popis	Signal	Oblast	Rozsah	Jed	Vyr	Typ	Vyr	Dod	Rozsah	Jed	Nastaveno
1	00EGD20CP051	XG11	PD Fil Topol	Kontakt 48 V s Hildanim	DALKTOP	0,5 bar								
2	00NDC11CP055	XG11	PD OI/Fil CerpTopVo 11	Kontakt 48 V s Hildanim	DALKTOP	bar								
3	00NDC12CP055	XG11	PD OI/Fil CerpTopVo 12	Kontakt 48 V s Hildanim	DALKTOP	bar								
4	00NDC13CP055	XG11	PD OI/Fil CerpTopVo 13	Kontakt 48 V s Hildanim	DALKTOP	bar								
5	00NDC14CP055	XG11	PD OI/Fil CerpTopVo 14	Kontakt 48 V s Hildanim	DALKTOP	bar								
6	08LAS10CP050	XG11	PD Fil pred NouzCerpNapV	Kontakt 48 V s Hildanim	VO PAR	bar								
7	70LAB20CP001	XQ50	PD RV NapVo K70	4 - 20 mA	K70	0 15 bar				H&B	ASK 800	0 16 bar	0 15 bar	
8	80HAD10CT040	XQ50	TD Stebub	4 - 20 mA	K80	0 600 °C				Rössel	TS11	0 600 °C	0 600 °C	
9	80HAD10CT041	XQ50	TD Stebub	4 - 20 mA	K80	0 600 °C				Rössel	TS11	0 600 °C	0 600 °C	
10	80HAH50CT040	XQ50	TD StevysSbe	4 - 20 mA	K80	0 600 °C				Rössel	TS11	0 600 °C	0 600 °C	
11	80HAH50CT041	XQ50	TD StevysSbe	4 - 20 mA	K80	0 600 °C				Rössel	TS11	0 600 °C	0 600 °C	
12	80HHE10CP001	XQ50	PD UzSoup Uhl 1 pred VSK	4 - 20 mA	K80	0 50 mbar				Prip 14x2.5	H&B	ASK 800	0 60 mbar	0 50 mbar
13	80HHE20CP001	XQ50	PD UzSoup Uhl 1 pred VSK	4 - 20 mA	K80	0 50 mbar				Prip 14x2.5	H&B	ASK 800	0 60 mbar	0 50 mbar
14	80HNC10CP052	XG11	PD na OI/Fil RegsSpoj KV	Kontakt 48 V s Hildanim	K80	0,6 bar								
15	80LAB30CP012	XQ50	PD RV NapVo K80	4 - 20 mA	VO PAR	0 30 bar				H&B	ASK 800	0 40 bar	0 30 bar	
16	80LAC11CP050	XG11	PD Fil NapVo 80/11	Kontakt 48 V s Hildanim	VO PAR	3 bar								
17	80LAC11CP061	XG11	PD OI/Fil CerpNapVo 80/11	Kontakt 48 V s Hildanim	VO PAR	bar								
18	80LAC12CP050	XG11	PD Fil NapVo 80/12	Kontakt 48 V s Hildanim	VO PAR	3 bar								
19	80LAC12CP061	XG11	PD OI/Fil CerpNapVo 80/12	Kontakt 48 V s Hildanim	VO PAR	bar								
20	80LBQ30CP901	XM39	PD Odbe A3-A2	Kontakt 48 V bez Hildani	T80	0 10 bar								
21	80LBQ30CP901	XM40	PD Odbe A3-A2	Kontakt 48 V bez Hildani	T80	0 10 bar								
22	80LBQ30CP901	XM41	Krit PD Odbe A3-A2	Kontakt 48 V bez Hildani	T80	0 10 bar								
23	80MVE01CP051	XG01	PD FilZvedOl	Kontakt 48 V bez Hildani	T80	4,2 bar								
24	90HAD10CT040	XQ50	TD Stebub	4 - 20 mA	K90	0 600 °C				H&B	TS11	0 600 °C	0 600 °C	
25	90HAD10CT041	XQ50	TD Stebub	4 - 20 mA	K90	0 600 °C				H&B	TS11	0 600 °C	0 600 °C	
26	90HAH50CT040	XQ50	TD StevysSbe	4 - 20 mA	K90	0 600 °C				H&B	TS11	0 600 °C	0 600 °C	
27	90HAH50CT041	XQ50	TD StevysSbe	4 - 20 mA	K90	0 600 °C				H&B	TS11	0 600 °C	0 600 °C	
28	90HHE10CP001	XQ50	PD UzSoup Uhl 1 pred VSK	4 - 20 mA	K90	0 50 mbar				H&B	ASK 800	0 60 mbar	0 50 mbar	
29	90HHE20CP001	XQ50	PD UzSoup Uhl 1 pred VSK	4 - 20 mA	K90	0 50 mbar				H&B	ASK 800	0 60 mbar	0 50 mbar	
30	90HNC10CP052	XG11	PD na OI/Fil RegsSpoj KV	Kontakt 48 V s Hildanim	K90	0,6 bar								
31	90LAB30CP012	XQ50	PD RV NapVo K90	4 - 20 mA	VO PAR	0 15 bar				H&B	ASK 800	0 40 bar	0 15 bar	
32	90LAC11CP050	XG11	PD NapVoFil 90/11	Kontakt 48 V s Hildanim	VO PAR	3 bar								
33	90LAC11CP061	XG11	PD OI/Fil NapVoCerp 90/11	Kontakt 48 V s Hildanim	VO PAR									
34	90LAC11CP062	XG11	PD OI/SpiKanapVoCerp90/11	Kontakt 48 V s Hildanim	VO PAR	1,2 bar		Herion	811773					
35	90LAC12CP050	XG11	PD NapVoFil 90/12	Kontakt 48 V s Hildanim	VO PAR	3 bar								
36	90LAC12CP061	XG11	PD OI/Fil NapVoCerp 90/12	Kontakt 48 V s Hildanim	VO PAR	bar								
37	90LBQ30CP901	XM39	PD Odbe A3-A2	Kontakt 48 V bez Hildani	T90	0 10 bar								
38	90LBQ30CP901	XM40	PD Odbe A3-A2	Kontakt 48 V bez Hildani	T90	0 10 bar								
39	90LBQ30CP901	XM41	Krit PD Odbe A3-A2	Kontakt 48 V bez Hildani	T90	0 10 bar								
40	90MVE01CP051	XG01	PD FilZvedOl	Kontakt 48 V bez Hildani	T90	4,2 bar								
41	Q3NDA01CP010	XQ50	PD Sit Stan HN1M1	4 - 20 mA	DALKTOP	0 500 kPa								
42	Q3NDA02CP010	XQ50	PD Sit Stan HN1M2	4 - 20 mA	DALKTOP	0 500 kPa								
43	Q3NDA03CP010	XQ50	PD Sit Stan HN1M3	4 - 20 mA	DALKTOP	0 500 kPa								
44	Q3NDA04CP010	XQ50	PD Sit Stan HN1M4	4 - 20 mA	DALKTOP	0 300 kPa								
45	Q3NDA11CP010	XQ50	PD Sit Stan HN1Z1	4 - 20 mA	DALKTOP	0 500 kPa								
46	Q3NDA12CP010	XQ50	PD Sit Stan HN1Z2	4 - 20 mA	DALKTOP	0 500 kPa								