

Po	KKS	Sig	Popis	TIak	Signál	Oblast	Rozsah	Jed	Vyr	Typ	Vyr	Dod	Rozsah	Jed	Nastaveno
1	00EGD20CP001	XQ50	P za CerpTopOl	4 - 20 mA	DALKTOP	0	25 bar	Prevk TI	H&B	AMD 200	ABB	0	40 bar	0	25 bar
2	00LAE11CP001	XQ50	P Vstřivo RedukStan 90	4 - 20 mA	VO PAR	0	40 bar	Prevk TI	H&B	AMD 200	ABB	0	250 bar	0	40 bar
3	00LAE12CP001	XQ50	P Vstřivo NajRedukStan	4 - 20 mA	VO PAR	0	40 bar	Prevk TI	H&B	AMD 200	ABB	0	250 bar	0	40 bar
4	00LAE13CP001	XQ50	P Vstřivo RezRedukStan	4 - 20 mA	VO PAR	0	40 bar	Prevk TI	H&B	AMD 200	ABB	0	250 bar	0	40 bar
5	00LAE14CP001	XQ50	P Vstřivo RedukStan 80	4 - 20 mA	VO PAR	0	40 bar	Prevk TI	H&B	AMD 200	ABB	0	250 bar	0	40 bar
6	00LAE15CP001	XQ50	P Vstřivo do RS PomParExt	4 - 20 mA	VO PAR	0	180 bar	Prevk TI	H&B	AMD 200	ABB	0	250 bar	0	40 bar
7	00LBA80CP001	XQ50	P VTPar Šbern	4 - 20 mA	VO PAR	0	160 bar	Prevk TI	H&B	AMD 200	ABB	0	250 bar	0	160 bar
8	00LBA80CP010	XQ50	P VTPar Šbern	4 - 20 mA	VO PAR	0	160 bar	Prevk TI	H&B	AMD 200	ABB	0	250 bar	0	160 bar
9	00LBA80CP011	XQ50	P VTPar Šbern	4 - 20 mA	VO PAR	0	160 bar	Prevk TI	H&B	AMD 200	ABB	0	250 bar	0	160 bar
10	00LBA80CP012	XQ50	P VTPar Šbern	4 - 20 mA	VO PAR	0	160 bar	Prevk TI	H&B	AMD 200	ABB	0	250 bar	0	160 bar
11	00LBA80CP020	XQ50	P VTPar Šbern	4 - 20 mA	VO PAR	0	160 bar	Prevk TI	H&B	AMD 200	ABB	0	250 bar	0	160 bar
12	00LBA82CP001	XQ50	P pred RedukStan RezOhr	4 - 20 mA	VO PAR	0	160 bar	Prevk TI	H&B	AMD 200	ABB	0	250 bar	0	160 bar
13	00LBA84CP001	XQ50	P Par pred NajRedukStan	4 - 20 mA	VO PAR	0	160 bar	Prevk TI	H&B	AMD 200	ABB	0	250 bar	0	160 bar
14	00LBS50CP001	XQ50	P PomPar 80	4 - 20 mA	VO PAR	0	10 bar	Prevk TI	H&B	AMD 220	ABB	0	16 bar	0	10 bar
15	00LBS50CP351	XG11	P Par RS PomParExCodb	Kontakt 48 V s Hlidaním	VO PAR	0	6,5 bar					0	16 bar		
16	00LBS80CP001	XQ50	P PomPar Šbern	4 - 20 mA	VO PAR	0	20 bar	Prevk TI	H&B	AMD 200	ABB	0	40 bar	0	20 bar
17	00LBS81CP001	XQ50	P PomPar 80	4 - 20 mA	VO PAR	0	20 bar	Prevk TI	H&B	AMD 200	ABB	0	40 bar	0	20 bar
18	00LBS81CP050	XG11	P PomPar 80	Kontakt 48 V s Hlidaním	VO PAR	0	16 bar					0	25 bar		
19	00LBSG3CP001	XQ50	P PomPar 90	4 - 20 mA	VO PAR	0	20 bar	Prevk TI	H&B	AMD 200	ABB	0	40 bar	0	20 bar
20	00LBSG3CP050	XG11	P PomPar 90	Kontakt 48 V s Hlidaním	VO PAR	0	20 bar					0	25 bar		
21	00NAA80CP001	XQ50	P za RS RezOhrTopVo	4 - 20 mA	VO PAR	0	10 bar	Prevk TI	H&B	AMD 220	BABC	0	16 bar	0	10 bar
22	00NAB81CP051	XG11	P pred Cerp1OTopKond	Kontakt 48 V s Hlidaním	KOND	0	16 bar					0	16 bar		
23	00NAB85CP001	XQ50	P Kond za RezTopOhr	4 - 20 mA	KOND	0	25 bar	Prevk TI	H&B	AMD 200	ABB	0	40 bar	0	25 bar
24	00NDA40CP001	XQ50	P TopVo Vyst	4 - 20 mA	DALKTOP	0	25 bar	Prevk TI	H&B	AMD 200	ABB	0	40 bar	0	25 bar
25	00NDA40CP002	XQ50	P TopVo Vyst	4 - 20 mA	DALKTOP	0	40 bar	Prevk TI	H&B	AMD 200	ABB	0	40 bar	0	25 bar
26	00NDA40CP351	XG11	P TopVo Vyst	Kontakt 48 V s Hlidaním	DALKTOP		25 bar					0	25 bar		
27	00NDA40CP352	XG11	P TopVo Vyst	Kontakt 48 V s Hlidaním	DALKTOP		25 bar					0	25 bar		
28	00NDB07CP001	XQ50	P TopVo	4 - 20 mA	DALKTOP	0	16 bar	Prevk TI	H&B	AMD 200	ABB	0	40 bar	0	16 bar
29	00NDB07CP002	XQ50	P TopVo	4 - 20 mA	DALKTOP	0	16 bar	Prevk TI	H&B	AMD 200	ABB	0	40 bar	0	16 bar
30	00NDB07CP003	XQ50	P TopVo	4 - 20 mA	DALKTOP	0	16 bar	Prevk TI	H&B	AMD 200	ABB	0	40 bar	0	16 bar
31	00NDB10CP001	XQ50	P TopVo Sit Vratik	4 - 20 mA	DALKTOP	0	25 bar	Prevk TI	H&B	AMD 200	ABB	0	40 bar	0	25 bar
32	00NDB15CP001	XQ50	P pred CerpTopVo	4 - 20 mA	DALKTOP	0	25 bar	Prevk TI	H&B	AMD 200	ABB	0	40 bar	0	25 bar
33	00NDB20CP301	XQ50	P TopVo Rozd za Cerp	4 - 20 mA	DALKTOP	0	25 bar	Prevk TI	H&B	AMD 200	ABB	0	40 bar	0	25 bar
34	00NDB20CP302	XQ50	P TopVo Rozd za Cerp	4 - 20 mA	DALKTOP	0	25 bar	Prevk TI	H&B	AMD 200	ABB	0	40 bar	0	25 bar
35	00NDB20CP303	XQ50	P TopVo Rozd za Cerp	4 - 20 mA	DALKTOP	0	25 bar	Prevk TI	H&B	AMD 200	ABB	0	40 bar	0	25 bar
36	00NDC11CP002	XQ50	P za CerpTopVo 11	4 - 20 mA	DALKTOP	0	25 bar	Prevk TI	H&B	AMD 200	ABB	0	40 bar	0	25 bar
37	00NDC11CP021	XQ50	P za Olfil CerpTopVo 11	4 - 20 mA	DALKTOP	0	6 bar	Prevk TI	H&B	AMD 220	ABB	0	16 bar	0	6 bar
38	00NDC11CP056	XG11	P za Olfil CerpTopVo 11	Kontakt 48 V s Hlidaním	DALKTOP		bar								
39	00NDC11CP301	XQ50	P pred CerpTopVo 11	4 - 20 mA	DALKTOP	0	25 bar	Prevk TI	H&B	AMD 200	ABB	0	40 bar	0	25 bar
40	00NDC12CP002	XQ50	P za CerpTopVo 12	4 - 20 mA	DALKTOP	0	25 bar	Prevk TI	H&B	AMD 200	ABB	0	40 bar	0	25 bar
41	00NDC12CP021	XQ50	P za Olfil CerpTopVo 12	4 - 20 mA	DALKTOP	0	6 bar	Prevk TI	H&B	AMD 220	ABB	0	16 bar	0	6 bar
42	00NDC12CP056	XG11	P za Olfil CerpTopVo 12	Kontakt 48 V s Hlidaním	DALKTOP		bar								
43	00NDC12CP301	XQ50	P pred CerpTopVo 12	4 - 20 mA	DALKTOP	0	25 bar	Prevk TI	H&B	AMD 200	ABB	0	40 bar	0	25 bar
44	00NDC13CP002	XQ50	P za CerpTopVo 13	4 - 20 mA	DALKTOP	0	25 bar	Prevk TI	H&B	AMD 200	ABB	0	40 bar	0	25 bar

45	00NDC13CP021	XQ50	P za OIfil CerpTopVo 13	4 - 20 mA	DALKTOP	0	6 bar	Prevk TI	H&B	AMD 220	ABB	0	16 bar	0	6 bar
46	00NDC13CP056	XG11	P za OIfil CerpTopVo 13	Kontakt 48 V s Hildanim	DALKTOP		bar								
47	00NDC13CP301	XQ50	P pred CerpTopVo 13	4 - 20 mA	DALKTOP	0	25 bar	Prevk TI	H&B	AMD 200	ABB	0	40 bar	0	25 bar
48	00NDC14CP002	XQ50	P za CerpTopVo 14	4 - 20 mA	DALKTOP	0	25 bar	Prevk TI	H&B	AMD 200	ABB	0	40 bar	0	25 bar
49	00NDC14CP021	XQ50	P za OIfil CerpTopVo 14	4 - 20 mA	DALKTOP	0	6 bar	Prevk TI	H&B	AMD 220	ABB	0	16 bar	0	6 bar
50	00NDC14CP056	XG11	P za OIfil CerpTopVo 14	Kontakt 48 V s Hildanim	DALKTOP		bar								
51	00NDC14CP301	XQ50	P pred CerpTopVo 14	4 - 20 mA	DALKTOP	0	25 bar	Prevk TI	H&B	AMD 200	ABB	0	40 bar	0	25 bar
52	00NDC14CP001	XQ50	P TopVo Dekarbo Nadr	4 - 20 mA	DALKTOP	0	16 bar							0	2,5 bar
53	00PAR10CP001	XQ50	P PrumyslVo	4 - 20 mA	KOND	0	10 bar	Prevk TI	H&B	AMD 220	ABB	0	16 bar	0	10 bar
54	00QEB20CP001	XQ50	P PracVzd Skoda ZavdSit	4 - 20 mA	K80	0	10 bar	Prevk TI	H&B	AMD 220	ABB	0	16 bar	0	10 bar
55	00QFB81CP001	XQ50	P RidVzdSys	4 - 20 mA	K80	0	16 bar	Prevk TI	H&B	AMD 220	ABB	0	16 bar	0	10 bar
56	00QFB91CP001	XQ50	P RidVzdSys	4 - 20 mA	K90	0	16 bar	Prevk TI	H&B	AMD 220	ABB	0	16 bar	0	10 bar
57	00SGA15CP053	XG01	TI pred Cerp	Kontakt 48 V bez Hildani	VLSPOTR										
58	00SGA15CP054	XG01	TI za Cerp	Kontakt 48 V bez Hildani	VLSPOTR										
59	08NDA10CP301	XG11	P TopVo za RezOhrTopVo	Kontakt 48 V s Hildanim	DALKTOP		5 bar					0	16 bar		
60	70HAA10CP001	XQ50	P Vo VHV Vst	4 - 20 mA	K70	0	40 bar	Prevk TI	H&B	AMD 200	ABB	0	250 bar	0	40 bar
61	70HAA10CP011	XQ50	P Vo VHV Vst	4 - 20 mA	K70	0	40 bar	Prevk TI	H&B	AMD 200	ABB	0	250 bar	0	40 bar
62	70HAD10CP001	XQ50	P Bub	4 - 20 mA	K70	0	250 bar	Prevk TI	H&B	AMD 200	ABB	0	600 bar	0	250 bar
63	70HAN03CP001	XQ50	P Expd	4 - 20 mA	K70	0	1 bar	Prevk TI	H&B	AMD 220	ABB	0	2,5 bar	0	1 bar
64	70HBK01CP001	XQ50	P Spalkom	4 - 20 mA	K70	0	100 mbar	Prevk TI	H&B	AMD 220	ABB	0	400 mbar	0	100 mbar
65	70HBK04CP001	XQ50	P Spn Kot Vst	4 - 20 mA	K70	-50	100 mbar	Prevk TI	H&B	AMD 220	ABB	0	400 mbar	-50	100 mbar
66	70LAB20CP002	XQ50	P za RV NapVo	4 - 20 mA	K70	0	250 bar	Prevk TI	H&B	AMD 200	ABB	0	600 bar	0	250 bar
67	70LBA10CP011	XQ50	P OP	4 - 20 mA	K70	0	200 bar	Prevk TI	H&B	AMD 200	ABB	0	250 bar	0	200 bar
68	70LBA10CP020	XQ50	P Potr OP	4 - 20 mA	K70	0	160 bar	Prevk TI	H&B	AMD 200	ABB	0	250 bar	0	160 bar
69	80ETG20CP051	XG11	P VyhPopfIuVst 2	Kontakt 48 V s Hildanim	K80										
70	80ETG20CP052	XG11	P VyhPopfIuVst 12	Kontakt 48 V s Hildanim	K80										
71	80ETP60CP001	XQ50	P Red DopVzd	4 - 20 mA	K80	0	6 bar	Prevk TI	H&B	AMD 200	ABB	0	16 bar	0	6 bar
72	80HCW10CP001	XQ50	P UcpVzd OfukKot	4 - 20 mA	K80	0	60 mbar	Prevk TI	H&B	AMD 220	ABB	0	400 mbar	0	60 mbar
73	80HDA21CP051	XG11	P VzdPopVyh2	Kontakt 48 V s Hildanim	K80		bar								
74	80HDA21CP052	XG11	P VzdPopVyh12	Kontakt 48 V s Hildanim	K80		bar								
75	80HDA21CP053	XG11	P VzdPopVyh3	Kontakt 48 V s Hildanim	K80		bar								
76	80HDA21CP054	XG11	P VzdPopVyh13	Kontakt 48 V s Hildanim	K80		bar								
77	80HDA99CP051	XG11	P Vzd FilislofIuVst	Kontakt 48 V s Hildanim	K80	0	250 mbar				ABB	0	250 mbar		
78	80HDC10CP001	XQ50	P Pop ZpPropst	4 - 20 mA	K80	0	500 mbar	Prevk TI	H&B	AMD 220	ABB	0	2,5 bar	0	500 mbar
79	80HDC10CP002	XQ50	P Pop ZpPropst	4 - 20 mA	K80	0	500 mbar	Prevk TI	H&B	AMD 220	ABB	0	2,5 bar	0	500 mbar
80	80HDC10CP003	XQ50	P Pop ZpPropst	4 - 20 mA	K80	0	500 mbar	Prevk TI	H&B	AMD 220	ABB	0	2,5 bar	0	500 mbar
81	80HHC10CP001	XQ50	P VSK	4 - 20 mA	K80	0	40 mbar	Prevk TI	H&B	AMD 220	ABB	0	60 mbar	0	40 mbar
82	80HHC11CP001	XQ50	P VSK TrjsCelSte	4 - 20 mA	K80	0	160 mbar	Prevk TI	H&B	AMD 220	ABB	0	400 mbar	0	160 mbar
83	80HHC12CP001	XQ50	P VSK Trjs PravBocSte	4 - 20 mA	K80	0	160 mbar	Prevk TI	H&B	AMD 220	ABB	0	400 mbar	0	160 mbar
84	80HHC12CP011	XQ50	P VSK SpSekVzd SteRez	4 - 20 mA	K80	0	100 mbar	Prevk TI	H&B	AMD 220	ABB	0	400 mbar	0	100 mbar
85	80HHC12CP021	XQ50	P VSK HsekVzd SteRez	4 - 20 mA	K80	0	80 mbar	Prevk TI	H&B	AMD 220	ABB	0	400 mbar	0	80 mbar
86	80HHC13CP001	XQ50	P VSK Trjs ZadSte	4 - 20 mA	K80	0	160 mbar	Prevk TI	H&B	AMD 220	ABB	0	400 mbar	0	160 mbar
87	80HHC14CP001	XQ50	P VSK Trjs LevBocSte	4 - 20 mA	K80	0	160 mbar	Prevk TI	H&B	AMD 220	ABB	0	400 mbar	0	160 mbar
88	80HHC14CP011	XQ50	P VSK SpSekVzd LevBocSte	4 - 20 mA	K80	0	100 mbar	Prevk TI	H&B	AMD 220	ABB	0	400 mbar	0	100 mbar
89	80HHC14CP021	XQ50	P VSK HsekVzd LevBocSte	4 - 20 mA	K80	0	80 mbar	Prevk TI	H&B	AMD 220	ABB	0	400 mbar	0	80 mbar
90	80HHE10CP002	XQ50	P SpadSacht 1 pred Kot	4 - 20 mA	K80	0	160 mbar	Prevk TI	H&B	AMD 220	ABB	0	400 mbar	0	160 mbar
91	80HHE20CP002	XQ50	P SpadSacht 2 pred Kot	4 - 20 mA	K80	0	160 mbar	Prevk DIF TI	H&B	AMD 220	ABB	0	400 mbar	0	160 mbar
92	80HHI10CP001	XQ50	P TridicPop	4 - 20 mA	K80	0	160 mbar	Prevk TI	H&B	AMD 220	ABB	0	400 mbar	0	160 mbar

93	80HH110CP002	XQ50	P TrdicPop	4 - 20 mA	K80	0	160 mbar	Prevk TI	H&B	AMD 220	ABB	0	400 mbar	0	160 mbar
94	80HHQ01CP001	XQ50	P Vzdz za Ventr TrdicPop	4 - 20 mA	K80	0	300 mbar	Prevk TI	H&B	AMD 220	ABB	0	400 mbar	0	300 mbar
95	80HJG01CP001	XQ50	P HlavPy pred Fil	4 - 20 mA	K80	0	4 bar	Prevk TI	H&B	AMD 200	ABB	0	16 bar	0	4 bar
96	80HJX01CP001	XQ50	P OV Vzdz NajHor	4 - 20 mA	K80	0	10 bar	Prevk TI	H&B	AMD 220	ABB	0	16 bar	0	10 bar
97	80HLA03CP001	XQ50	P Vzdz za VV	4 - 20 mA	K80	0	300 mbar	Prevk TI	H&B	AMD 220	ABB	0	400 mbar	0	300 mbar
98	80HLA04CP001	XQ50	P Vzdz za ParlUVO	4 - 20 mA	K80	0	300 mbar	Prevk TI	H&B	AMD 220	ABB	0	400 mbar	0	300 mbar
99	80HNA02CP001	XQ50	P za Cyk	4 - 20 mA	K80	-10	10 mbar	Prevk TI	H&B	AMD 220	ABB	0	60 mbar	-10	10 mbar
100	80HNA03CP001	XQ50	P SpIn pred LUVO	4 - 20 mA	K80	-40	20 mbar	Prevk TI	H&B	AMD 220	ABB	0	400 mbar	-40	20 mbar
101	80HNA04CP001	XQ50	P SpIn pred HadFil	4 - 20 mA	K80	-50	20 mbar	Prevk TI	H&B	AMD 220	ABB	0	400 mbar	-50	20 mbar
102	80HNA06CP001	XQ50	P SpIn za KV	4 - 20 mA	K80	-10	5 mbar	Prevk TI	H&B	AMD 220	ABB	0	60 mbar	-10	5 mbar
103	80HNC10CP061	XG11	P MazOI Loz KV	Kontakt 48 V s Hildanim	K80		0,6 bar								
104	80HNC10CP063	XG11	P MazOI Loz KV	Kontakt 48 V s Hildanim	K80		0,6 bar								
105	80HNC10CP065	XG11	P MazOI Loz KV	Kontakt 48 V s Hildanim	K80		0,6 bar								
106	80HNC10CP067	XG11	P SpIn Recikl k PrimVzd	Kontakt 48 V s Hildanim	K80		0,6 bar								
107	80HNF01CP001	XQ50	P SpIn Recikl k PrimVzd	4 - 20 mA	K80	0	300 mbar	Prevk TI	H&B	AMD 220	ABB	0	400 mbar	0	300 mbar
108	80HNA10CP002	XQ50	P Pop VyslCyk	4 - 20 mA	K80	-30	30 mbar	Prevk TI	H&B	AMD 220	ABB	0	400 mbar	-30	30 mbar
109	80HTS21CP001	XQ50	P za VentrDoprVzd 1	4 - 20 mA	K80	0	1 bar	Prevk TI	H&B	AMD 220	ABB	0	2,5 bar	0	1 bar
110	80HTS22CP001	XQ50	P za VentrDoprVzd 2	4 - 20 mA	K80	0	1 bar	Prevk TI	H&B	AMD 220	ABB	0	2,5 bar	0	1 bar
111	80LAA10CP001	XQ50	P NadrNapVo 80	4 - 20 mA	VO PAR	0	10 bar	Prevk TI	H&B	AMD 220	ABB	0	16 bar	0	10 bar
112	80LAA10CP051	XG11	P NadrNapVo 80	Kontakt 48 V s Hildanim	VO PAR		10 bar								
113	80LAB30CP011	XQ50	P NapVo pred RV NapVo	4 - 20 mA	VO PAR	0	180 bar	Prevk TI	H&B	AMD 200	ABB	0	250 bar	0	180 bar
114	80LAB30CP013	XQ50	P NapVo pred EKO	4 - 20 mA	K80	0	180 bar	Prevk TI	H&B	AMD 200	ABB	0	250 bar	0	180 bar
115	80LAC11CP001	XQ50	P pred CerpNapVo 80/11	4 - 20 mA	VO PAR	0	10 bar	Prevk TI	H&B	AMD 220	ABB	0	16 bar	0	10 bar
116	80LAC11CP002	XQ50	P za CerpNapVo 80/11	4 - 20 mA	VO PAR	0	250 bar	Prevk TI	H&B	AMD 200	ABB	0	600 bar	0	250 bar
117	80LAC11CP010	XQ50	P NapVo Sbern 80	4 - 20 mA	VO PAR	0	250 bar	Prevk TI	H&B	AMD 200	ABB	0	600 bar	0	250 bar
118	80LAC11CP020	XQ50	P Ol za Chiac 80/11	4 - 20 mA	VO PAR	0	10 bar	Prevk TI	H&B	AMD 220	ABB	0	16 bar	0	6 bar
119	80LAC11CP062	XG11	P OISpoj CerpNapVo 80/11	Kontakt 48 V s Hildanim	VO PAR		1,2 bar								
120	80LAC11CP063	XG11	P Ol za Ofil 80/11	Kontakt 48 V s Hildanim	VO PAR		1,5 bar								
121	80LAC12CP001	XQ50	P pred CerpNapVo 80/12	4 - 20 mA	VO PAR	0	10 bar	Prevk TI	H&B	AMD 220	ABB	0	16 bar	0	10 bar
122	80LAC12CP002	XQ50	P za CerpNapVo 80/12	4 - 20 mA	VO PAR	0	250 bar	Prevk TI	H&B	AMD 200	ABB	0	600 bar	0	250 bar
123	80LAC12CP020	XQ50	P Ol za Chiac 80/12	4 - 20 mA	VO PAR	0	10 bar	Prevk TI	H&B	AMD 220	ABB	0	16 bar	0	6 bar
124	80LAC12CP062	XG11	P OISpoj CerpNapVo 80/12	Kontakt 48 V s Hildanim	VO PAR		1,2 bar								
125	80LAC12CP063	XG11	P Ol za Ofil 80/12	Kontakt 48 V s Hildanim	VO PAR		1,6 bar								
126	80LAE45CP001	XQ50	P VstirVo CerpNapVo 80	4 - 20 mA	VO PAR	0	25 bar	Prevk TI	H&B	AMD 200	ABB	0	40 bar	0	35 bar
127	80LBA10CP001	XQ50	P OP K80	4 - 20 mA	VO PAR	0	160 bar	Prevk TI	H&B	AMD 200	ABB	0	250 bar	0	160 bar
128	80LBA10CP002	XQ50	P OP	4 - 20 mA	VO PAR	0	160 bar	Prevk TI	H&B	AMD 200	ABB	0	250 bar	0	160 bar
129	80LBA20CP001	XQ50	P OP	4 - 20 mA	VO PAR	0	160 bar	Prevk TI	H&B	AMD 200	ABB	0	250 bar	0	160 bar
130	80LBA20CP002	XQ50	P OP pred Turb 80	4 - 20 mA	VO PAR	0	160 bar	Prevk TI	H&B	AMD 200	ABB	0	250 bar	0	160 bar
131	80LBA20CP003	XQ01	P OP pred Turb	4 - 20 mA	T80	0	160 bar								
132	80LBA20CP004	XQ01	P OP pred Turb	4 - 20 mA	T80	0	160 bar								
133	80LBD10CP010	XG01	P OdebePar	4 - 20 mA	T80	-1	4 bar								
134	80LBD10CP001	XMG5	P OdebePar Mer1	Kontakt 48 V bez Hildani	T80	-1	4 bar								
135	80LBD10CP001	XMG6	P OdebePar Mer2	Kontakt 48 V bez Hildani	T80	-1	4 bar								
136	80LBD10CP001	XMG7	P OdebePar Mer3	Kontakt 48 V bez Hildani	T80	-1	4 bar								
137	80LBD10CP001	XMG8	P OdebePar 3	Kontakt 48 V bez Hildani	T80	-1	4 bar								
138	80LBD10CP001	XMG9	P OdebePar	Kontakt 48 V bez Hildani	T80	-1	4 bar								
139	80LBD10CP001	XMG40	P OdebePar A2	Kontakt 48 V bez Hildani	T80	-1	4 bar								
140	80LBD10CP001	XMG41	Krit P OdebePar	Kontakt 48 V bez Hildani	T80	-1	4 bar								

141	80LBD10CP901	XQ01	P OdbEPar	4 - 20 mA	T80	-1	4 bar											
142	80LBQ10CP010	XQ01	P OdbEPar A5	4 - 20 mA	T80	-1	49 bar											
143	80LBQ20CP010	XQ01	P OdbEPar A4	4 - 20 mA	T80	-1	24 bar											
144	80LBQ30CP010	XQ01	P OdbEPar A3	4 - 20 mA	T80	-1	9 bar											
145	80LBQ30CP901	XM35	OchrObvod sirna	Kontakt 48 V bez Hlidaní	T80	0	10 bar											
146	80LBQ30CP901	XM36	P OdbE A3 Mer1	Kontakt 48 V bez Hlidaní	T80	0	10 bar											
147	80LBQ30CP901	XM37	P OdbE A3 Mer2	Kontakt 48 V bez Hlidaní	T80	0	10 bar											
148	80LBQ30CP901	XM38	P OdbE A3 Mer3	Kontakt 48 V bez Hlidaní	T80	0	10 bar											
149	80LBQ30CP901	XQ01	P OdbE A3	4 - 20 mA	T80	-1	9 bar											
150	80LBS20CP010	XQ01	P OdbEPar A1	4 - 20 mA	T80	-1	0,6 bar											
151	80LCA20CP001	XQ01	P Kond	4 - 20 mA	T80	0	25 bar											
152	80LCA60CP010	XQ50	P Kond pred NadrNapV 80	4 - 20 mA	VO PAR	0	10 bar	Prevk TI	H&B	AMD 220	ABB	0	16 bar	0	10 bar			
153	80LCL10CP001	XQ50	P VypouExpd	4 - 20 mA	K80	0	2,5 bar	Prevk TI	H&B	AMD 200	ABB	0	16 bar	0	2,5 bar			
154	80LCM20CP001	XQ50	P Nadr ProvKond	4 - 20 mA	KOND	0	1,6 bar	Prevk TI	H&B	AMD 220	ABB	0	2,5 bar	0	1,6 bar			
155	80MAA10CP010	XQ01	P pred VT Stup	4 - 20 mA	T80	-1	149 bar											
156	80MAC10CP001	XQ01	P pred NT Stup	4 - 20 mA	T80	-1	4 bar											
157	80MAC10CP901	XM35	Krit P OdbpadPar	Kontakt 48 V bez Hlidaní	T80		bar											
158	80MAC10CP901	XM36	P OdbpadPar Mer1	Kontakt 48 V bez Hlidaní	T80		bar											
159	80MAC10CP901	XM37	P OdbpadPar Mer2	Kontakt 48 V bez Hlidaní	T80		bar											
160	80MAC10CP901	XM38	P OdbpadPar Mer3	Kontakt 48 V bez Hlidaní	T80		bar											
161	80MAC10CP901	XM39	P OdbpadPar	Kontakt 48 V bez Hlidaní	T80		bar											
162	80MAC10CP901	XM40	P OdbpadPar	Kontakt 48 V bez Hlidaní	T80		bar											
163	80MAC10CP901	XM41	Krit P OdbpadPar	Kontakt 48 V bez Hlidaní	T80		bar											
164	80MAC10CP901	XQ01	P OdbpadPar	4 - 20 mA	T80	-1	0,6 bar											
165	80MAK50CP051	XG02	P ProtacZarHid	Kontakt 48 V bez Hlidaní	T80		0,5 bar											
166	80MAX01CP051	XG01	P FilioVoi	Kontakt 48 V bez Hlidaní	T80		0,9 bar											
167	80MAX02CP010	XQ01	P RZ Ol	4 - 20 mA	T80	0	16 bar											
168	80MAX02CF301	XG02	P RZ Ol	Kontakt 48 V bez Hlidaní	T80		1,5 bar											
169	80MAX03CP010	XQ01	P Naj Ol	4 - 20 mA	T80	0	16 bar											
170	80MAX04CP010	XQ01	P Zk Ol	4 - 20 mA	T80	0	10 bar											
171	80MAX06CP010	XQ01	P Zk Ol	4 - 20 mA	T80	0	10 bar											
172	80MAV57DU001	XG54	ZH Mer TI OdbE	4 - 20 mA	T80	-1	4 bar											
173	80MVB10CP010	XQ01	P OviOl	4 - 20 mA	T80	0	16 bar											
174	80MVB30CP010	XQ01	P MazOl	4 - 20 mA	T80	0	4 bar											
175	80MVB30CP051	XG01	P MazOlFil	Kontakt 48 V bez Hlidaní	T80		0,6 bar											
176	80MVB30CP901	XM35	P MazOl	Kontakt 48 V bez Hlidaní	T80		bar											
177	80MVB30CP901	XM40	P MazOl	Kontakt 48 V bez Hlidaní	T80		bar											
178	80MVE10CP010	XQ01	P ZvedOl	4 - 20 mA	T80	0	160 bar											
179	80NAA10CP010	XQ50	P NTPar pred TopOhr Bi80	4 - 20 mA	KOND	0	6 bar	Prevk TI	H&B	AMD 220	ABB	0	16 bar	0	6 bar			
180	80NAB11CP301	XQ50	P predCeip 10T opKond	4 - 20 mA	KOND	0	10 bar	Prevk TI	H&B	AMD 220	ABB	0	16 bar	0	10 bar			
181	80NAB20CP001	XQ50	P TopKond za TopOhr Bi80	4 - 20 mA	KOND	0	25 bar	Prevk TI	H&B	AMD 200	ABB	0	40 bar	0	25 bar			
182	80NDA10CP351	XG11	P TopVo za TopOhr BI 80	Kontakt 48 V s Hlidaním	DALKTOP		5 bar											
183	80PAB20CP001	XQ50	P HlChiaVo pred KondBi80	4 - 20 mA	CHLADVO	0	4 bar	Prevk TI	H&B	AMD 200	ABB	0	16 bar	0	4 bar			
184	80PAB20CP051	XG11	P HlChiaVo pred Kond 80	Kontakt 48 V s Hlidaním	CHLADVO	0	16 bar	Prevk TI	H&B	AMD 200	ABB	0	16 bar	0	4 bar			
185	80PGB30CP001	XQ50	P MezCChiaVo za VedChia	4 - 20 mA	CHLADVO	0	4 bar	Prevk TI	H&B	AMD 200	ABB	0	16 bar	0	4 bar			
186	80PGB40CP001	XQ50	P MezCChiaVo za Ceip	4 - 20 mA	CHLADVO	0	10 bar	Prevk TI	H&B	AMD 220	ABB	0	16 bar	0	10 bar			
187	80PGB80CP001	XQ50	P MezCChiaVopredVedChia	4 - 20 mA	CHLADVO	0	4 bar	Prevk TI	H&B	AMD 200	ABB	0	16 bar	0	4 bar			
188	80QEB01CP001	XQ50	P DoprvZd	4 - 20 mA	K80	0	6 bar	Prevk TI	H&B	AMD 220	ABB	0	16 bar	0	6 bar			

[illegible]

237	90LAC11CP010	XQ50	P NapVo Sbern 90	4 - 20 mA	VO PAR	0	250 bar	Prevk TI	H&B	AMD 200	ABB	0	600 bar	0	250 bar
238	90LAC11CP020	XQ50	P OI za Chiac 90/11	4 - 20 mA	VO PAR	0	10 bar	Prevk TI	H&B	AMD 220	ABB	0	16 bar	0	10 bar
239	90LAC11CP063	XG11	P OI za OIfil 90/11	Kontakt 48 V s Hildanim	VO PAR		1,5 bar								
240	90LAC12CP001	XQ50	P pred NapVoCerp 90/12	4 - 20 mA	VO PAR	0	10 bar	Prevk TI	H&B	AMD 220	ABB	0	16 bar	0	10 bar
241	90LAC12CP002	XQ50	P za NapVoCerp 90/12	4 - 20 mA	VO PAR	0	250 bar	Prevk TI	H&B	AMD 200	ABB	0	600 bar	0	250 bar
242	90LAC12CP020	XQ50	P OI za Chiac 90/12	4 - 20 mA	VO PAR	0	10 bar	Prevk TI	H&B	AMD 220	ABB	0	16 bar	0	10 bar
243	90LAC12CP062	XG11	P OI Spjka NapVoCerp90/12	Kontakt 48 V s Hildanim	VO PAR		1,2 bar								
244	90LAC12CP063	XG11	P OI za OIfil 90/12	Kontakt 48 V s Hildanim	VO PAR		1,6 bar								
245	90LAE45CP001	XQ50	P VstrivVo CerpNapVo 90	4 - 20 mA	VO PAR	0	25 bar	Prevk TI	H&B	AMD 200	ABB	0	40 bar	0	25 bar
246	90LBA10CP001	XQ50	P OP K90	4 - 20 mA	VO PAR	0	160 bar	Prevk TI	H&B	AMD 200	ABB	0	250 bar	0	160 bar
247	90LBA10CP002	XQ50	P OP K90	4 - 20 mA	VO PAR	0	160 bar	Prevk TI	H&B	AMD 200	ABB	0	250 bar	0	160 bar
248	90LBA20CP001	XQ50	P OP pred Turb 90	4 - 20 mA	VO PAR	0	160 bar	Prevk TI	H&B	AMD 200	ABB	0	250 bar	0	160 bar
249	90LBA20CP002	XQ50	P OP pred Turb 90	4 - 20 mA	VO PAR	0	160 bar	Prevk TI	H&B	AMD 200	ABB	0	250 bar	0	160 bar
250	90LBA20CP003	XQ01	P OP pred Turb	4 - 20 mA	T90	0	160 bar	Prevk TI	H&B	AMD 200	ABB	0	250 bar	0	160 bar
251	90LBA20CP004	XQ01	P OP pred Turb	4 - 20 mA	T90	0	160 bar								
252	90LBD10CP010	XQ01	P OdbePar	4 - 20 mA	T90	-1	4 bar								
253	90LBD10CP001	XM35	P OdbePar Mer1	Kontakt 48 V bez Hildani	T90	-1	4 bar								
254	90LBD10CP001	XM36	P OdbePar Mer2	Kontakt 48 V bez Hildani	T90	-1	4 bar								
255	90LBD10CP001	XM37	P OdbePar Mer3	Kontakt 48 V bez Hildani	T90	-1	4 bar								
256	90LBD10CP001	XM38	P OdbePar 3	Kontakt 48 V bez Hildani	T90	-1	4 bar								
257	90LBD10CP001	XM39	P OdbePar	Kontakt 48 V bez Hildani	T90	-1	4 bar								
258	90LBD10CP001	XM40	P OdbePar A2	Kontakt 48 V bez Hildani	T90	-1	4 bar								
259	90LBD10CP001	XM41	Krit P OdbePar	Kontakt 48 V bez Hildani	T90	-1	4 bar								
260	90LBD10CP001	XQ01	P OdbePar	4 - 20 mA	T90	-1	4 bar								
261	90LBQ10CP010	XQ01	P OdbePar A5	4 - 20 mA	T90	-1	49 bar								
262	90LBQ20CP010	XQ01	P OdbePar A4	4 - 20 mA	T90	-1	24 bar								
263	90LBQ30CP010	XQ01	P OdbePar A3	4 - 20 mA	T90	-1	9 bar								
264	90LBQ30CP001	XM35	OchrObvod šbirna	Kontakt 48 V bez Hildani	T90	0	10 bar								
265	90LBQ30CP001	XM36	P Odbe A3 Mer1	Kontakt 48 V bez Hildani	T90	0	10 bar								
266	90LBQ30CP001	XM37	P Odbe A3 Mer2	Kontakt 48 V bez Hildani	T90	0	10 bar								
267	90LBQ30CP001	XM38	P Odbe A3 Mer3	Kontakt 48 V bez Hildani	T90	0	10 bar								
268	90LBQ30CP001	XQ01	P Odbe A3	4 - 20 mA	T90	-1	9 bar								
269	90LBS20CP010	XQ01	P OdbePar A1	4 - 20 mA	T90	-1	0,6 bar								
270	90LCA20CP001	XQ01	P Kond	4 - 20 mA	T90	0	25 bar								
271	90LCA60CP010	XQ50	P Kond pred NadrNapVo 90	4 - 20 mA	KOND	0	10 bar	Prevk TI	H&B	AMD 220	ABB	0	16 bar	0	10 bar
272	90LCL10CP001	XQ50	P VypouExpd	4 - 20 mA	K90	0	2,5 bar	Prevk TI	H&B	AMD 200	ABB	0	16 bar	0	2,5 bar
273	90LCM20CP001	XQ50	P ProvKond SbeNadr	4 - 20 mA	KOND	0	1,6 bar	Prevk TI	H&B	AMD 220	ABB	0	2,5 bar	0	1,6 bar
274	90MAA10CP010	XQ01	P pred VT Stup	4 - 20 mA	T90	-1	149 bar								
275	90MAC10CP001	XQ01	P pred NT Stup	4 - 20 mA	T90	-1	4 bar								
276	90MAC10CP001	XM35	Krit P OdpadPar	Kontakt 48 V bez Hildani	T90		bar								
277	90MAC10CP001	XM36	P OdpadPar Mer1	Kontakt 48 V bez Hildani	T90		bar								
278	90MAC10CP001	XM37	P OdpadPar Mer2	Kontakt 48 V bez Hildani	T90		bar								
279	90MAC10CP001	XM38	P OdpadPar Mer3	Kontakt 48 V bez Hildani	T90		bar								
280	90MAC10CP001	XM39	P OdpadPar	Kontakt 48 V bez Hildani	T90		bar								
281	90MAC10CP001	XM40	P OdpadPar	Kontakt 48 V bez Hildani	T90		bar								
282	90MAC10CP001	XM41	Krit P OdpadPar	Kontakt 48 V bez Hildani	T90		bar								
283	90MAC10CP001	XQ01	P OdpadPar	4 - 20 mA	T90	-1	0,6 bar								
284	90MAK50CP051	XG02	P ProtacZarHid	Kontakt 48 V bez Hildani	T90		0,5 bar								

285	90MAX01CP051	XG01	P FI/OI/OI	Kontakt 48 V bez Hlidaní	T90		0,9 bar											
286	90MAX02CP010	XQ01	P RZ OI	4 - 20 mA	T90	0	16 bar											
287	90MAX02CP301	XG02	P RZ OI	Kontakt 48 V bez Hlidaní	T90		1,5 bar											
288	90MAX03CP010	XQ01	P Naj OI	4 - 20 mA	T90	0	16 bar											
289	90MAX04CP010	XQ01	P Zk OI	4 - 20 mA	T90	0	10 bar											
290	90MAX06CP010	XQ01	P Zk OI	4 - 20 mA	T90	0	10 bar											
291	90MAX57DU001	XG54	ZH Mer TI/Odbe	4 - 20 mA	T90	-1	4 bar											
292	90MVB10CP010	XQ01	P OVI/OI	4 - 20 mA	T90	0	16 bar											
293	90MVB30CP010	XQ01	P MazOI	4 - 20 mA	T90	0	4 bar											
294	90MVB30CP051	XG01	P MazOI/Fil	Kontakt 48 V bez Hlidaní	T90		0,6 bar											
295	90MVB30CP901	XM35	P MazOI	Kontakt 48 V bez Hlidaní	T90		bar											
296	90MVB30CP901	XM40	P MazOI	Kontakt 48 V bez Hlidaní	T90		bar											
297	90MVE10CP010	XQ01	P ZvedOI	4 - 20 mA	T90	0	160 bar											
298	90NAA10CP010	XQ50	P NTPar pred TopOhr BI90	4 - 20 mA	KOND	0	6 bar	Prevk TI	H&B	AMD 220	ABB	0	16 bar	0		6 bar		
299	90NAB11CP301	XQ50	P predCerp 10TtopKond	4 - 20 mA	KOND	0	10 bar	Prevk TI	H&B	AMD 220	ABB	0	16 bar	0		10 bar		
300	90NAB20CP001	XQ50	P TopKond za TopOhr BI90	4 - 20 mA	KOND	0	25 bar	Prevk TI	H&B	AMD 200	ABB	0	40 bar	0		25 bar		
301	90NDA10CP351	XG11	P TopVo za TopOhr BI 90	Kontakt 48 V s Hlidaním	DALKTOP		5 bar				ABB	0	25 bar					
302	90PAB20CP001	XQ50	P HIChlaVo pred KondBI90	4 - 20 mA	CHLADVO	0	4 bar	Prevk Dif TI	H&B	AMD 220	ABB	0	16 bar	0		4 bar		
303	90PAB20CP051	XG11	P HIChlaVo pred Kond 90	Kontakt 48 V s Hlidaním	CHLADVO		16 bar				ABB	0	16 bar					
304	90PGB30CP001	XQ50	P MeziChlaVo za VediChla	4 - 20 mA	CHLADVO	0	4 bar	Prevk TI	H&B	AMD 200	ABB	0	16 bar	0		4 bar		
305	90PGB40CP001	XQ50	P MeziChlaVo za VoCerp	4 - 20 mA	CHLADVO	0	10 bar	Prevk TI	H&B	AMD 220	ABB	0	16 bar	0		10 bar		
306	90PGB80CP001	XQ50	P MeziChlaVopredVediChla	4 - 20 mA	CHLADVO	0	4 bar	Prevk TI	H&B	AMD 200	ABB	0	16 bar	0		4 bar		
307	90QEB01CP001	XQ50	P DopriVzd	4 - 20 mA	K90	0	6 bar	Prevk TI	H&B	AMD 220	ABB	0	16 bar	0		6 bar		

