

a) V KOMUNIKACI

b) VE VOLNÉM TERÉNU

500

KÓTA TERÉNU

KONSTRUKCE VOZOVKY

PROVEDENÍ OPRAVY KOMUNIKACE A CHODNIKY DLE POŽADAVKŮ SPRÁVCE MAITELE KOMUNIKACE A CHODNIKY

ZÁSYP HUTNĚNÝ PO VRSTVÁCH (ŠTĚRKODRŤ (ŠTĚRKOPÍSEK))

PAŽENÍ

OBSYP POTRUBÍ ŠTĚRKOPÍSEK

POTRUBÍ

ULTRA SOLID BP SN12 400x12,6, 315x10,0, 250x8,1, 200x6,5, 160x5,3 PLNOSTĚNNÉ (MODŘE)

300

D

100

ZATRÁVNĚNÍ + OHUMUSOVÁNÍ V TL. 150 mm

ZÁSYP HUTNĚNÝ PO VRSTVÁCH (ZEMINA Z VÝKOPU)

ÚROVEŇ PRO STROJNÍ HUTNĚNÍ (MIN. 300 mm NAD VRCHOLEM POTRUBÍ)

OBSYP POTRUBÍ ŠTĚRKOPÍSEK

LOŽE VÝKOPU ŠTĚRKOPÍSEK

DRENÁŽNÍ POTRUBÍ (V PŘÍPADĚ ODVODNĚNÍ STAVBY)

400mm
315mm
250mm
200,160mm

VNĚJŠÍ PRŮMĚR

1200mm – ŠÍŘKA RÝHY
1100mm – ŠÍŘKA RÝHY
1050mm – ŠÍŘKA RÝHY
1000mm – ŠÍŘKA RÝHY

(VIZ. ČSN EN 1610, prEN 1046)

- VÝKOPY NUTNO PAŽIT!!!
- OD HLOUBKY VÝKOPU 1,20 m BUDE RÝHA PAŽENA
- PAŽENÍ BUDE ODSTRAŇOVÁNO S POSTUPUJÍCÍM ZÁSYPEM
- PŘI REALIZACI NUTNO DODRŽOVAT VEŠKERÉ TECHNOLOGICKÉ POKYNY VÝROBCE MATERIÁLU
- PŘI REALIZACI NUTNO DODRŽOVAT POKYNY A POŽADAVKY SPRÁVCE KANALIZACE
- HLOUBKA ULOŽENÍ POTRUBÍ DLE PODÉLNÝCH PROFILŮ
- PŘI PROVÁDĚNÍ NUTNO DODRŽOVAT ZÁSADY BEZPEČNOSTI A OCHRANY ZDRAVÍ !

The drawing consists of two parts: a plan view (top) and a cross-section view (bottom).

Plan View (Top): Shows a rectangular layout of the sewerage system. On the left, a vertical line represents the "SPLAŠKOVÁ KANALIZACE" (storm sewerage), with a diameter symbol (a circle with a vertical line through it) and the label "PAŽENÍ" (manhole) at the top. On the right, a vertical line represents the "DEŠŤOVÁ KANALIZACE" (rain sewerage), also with a diameter symbol and the label "PAŽENÍ" at the top. Between these two lines, there are two horizontal lines representing "VODOVOD" (water supply pipes), each marked with a solid black circle. The entire plan view is enclosed in a rectangular frame.

Cross-section View (Bottom): Shows the vertical arrangement of the pipes. From top to bottom, the layers are:

- A top layer with a width of 150 units.
- A layer with a width of 250 units.
- A layer with a width of 1000 units.
- A layer with a width of 600 units.
- A layer with a width of 600 units.
- A bottom layer with a width of 250 units.
- A bottom-most layer with a width of 150 units.

 The layers are separated by horizontal lines with diagonal hatching on the sides.

Dimensions and Labels:

- Plan view labels: "SPLAŠKOVÁ KANALIZACE", "DEŠŤOVÁ KANALIZACE", "VODOVOD", "PAŽENÍ".
- Cross-section labels: "150", "250", "1000", "600", "600", "250", "150".
- Bottom text: "VZDÁLENOST DLE ČSN 73 6005 MEZI VNĚJŠÍMI POVRCHY POTRUBÍ" (Distance according to ČSN 73 6005 between the outer surfaces of the pipes).

ODP.PROJEKTANT	VÝPRACOVAL	KONTROLOVAL	HIP		
M.NOVOTNÁ	M.NOVOTNÁ	ing.P.BLÁHA	ing.J.MAREK		
OBEC : HAVLÍČKŮV BROD		OKRES : HAVLÍČKŮV BROD			
KRAJ : VYSOČINA					
INVESTOR : TECHNICKÉ SLUŽBY HAVLÍČKŮV BROD					
<i>Revitalizace areálu Technických služeb U Cihláře, Havlíčkův Brod</i>					
				DATUM	06/2025
				STUPEŇ PD	DSP
				Č. ZAKÁZKY	23020
<i>PŘÍČNÝ ŘEZ KANALIZAČNÍM POTRUBÍM</i>				MĚŘÍTKO	
				ČÁST DOKUM.	Č. VÝKRESU
				<i>D.1.301</i>	<i>10</i>