


Technical floor plan of a laboratory facility, showing various equipment and structural details. The plan includes a grid system with columns J, K, and L, and rows 039B and 039C. Key components and labels include:

- ODVĚTRÁNÍ VYVEDENO 1,5m NAD ÚROVĚN STŘECHY UKONČENO STRÍŠKOU**: Ventilation system with a roof-mounted rain cap.
- RP01 RP02 RP03 RP04 RP05**: A row of five circular components, likely part of a gas handling system.
- H CH4 He N Ar**: Labels for different gases.
- Přestup potrubí stěnou opatřen chráničkou**: Pipe transition through the wall with a protective cover.
- KONDENZÁTOR W01B**: Condenser unit.
- 2370**: Dimension indicating the distance between the condenser and the wall.
- NAPRAŠOVACÍ APARATURA**: Dusting equipment.
- CL. ±1900mm**: Ceiling level.
- APARATURA HOT FILAMENT**: Hot filament equipment.
- Potrubí vedeno pod parapetem v řadě pod sebou, lodběry svedeny visle dole ~900mm nad podlahu**: Pipe routing under the eave, with downpipes leading to a collection point ~900mm above the floor.
- 039B -3,350**: Room or area identifier.
- CHILLER W01A**: Chiller unit.
- APARATURA PLASMATICKÉ TRYSKY**: Plasma spray equipment.
- 1850**: Dimension indicating the width of the equipment area.
- 785** and **4700**: Vertical dimensions indicating the height of the equipment area.



Stavba	Laboratoř HFPJ - RF	
Místo stavby	Na Slovance 1999/2, 182 21 Praha 8	
Investor	Fyzikální ústav AV ČR, v.v.i.	
Stupeň PD	Dokumentace pro vydání společného ÚR a SP	
Díl PD	D.2 Dokumentace technických a technologických zařízení	
SO / PS		

Měřítko: 1:50 (1:25)	Formát: 2xA4	P. kopii: 6	Č. kopie:	Archivní číslo: 2-15101-D-00-222201 Soubor: 2-15101-D-00-222201-R0 Potr. dispozice	Revize: 0
--	---------------------	---------------------------	-----------	---	-------------------------

Tento dokument je majetkem společnosti AS CHEMOPRAG, a.s.. Nesmí být použit a kopírován třetí osobou, nebo jí předán, či jinak s ním nakládáno bez výslovného písemného souhlasu odpovědného zástupce společnosti.