

VZT P1 - Tabulka požárních klapek

Označení	Pozice dle specifikace	Umístění m.č.	Rozměr
PK1a	1.3	0.2	400X200
PK1b	1.3	0.2	400X200
PK2a	2.4	4.4	400x280
PK2b	2.4	4.4	400x280
PK3a	3.4	4.3	500x250
PK3b	3.5	4.3	450x250
PK4a	4.3	0.2	315x200
PK4b	4.3	0.2	315x200
PK5a	5.4	4.4	355x355
PK5b	5.4	4.4	355x355
PK5c	5.5	2.19	355x250
PK5d	5.6	2.19	450x250
PK5e	5.7	2.13	ø125
PK6a	6.4	4.3	315x250
PK6b	6.4	4.3	315x250
PK7a	7.4	4.4	355x200
PK7b	7.4	4.4	355x200
PK8a	8.4	4.3	400x250
PK8b	8.4	4.3	400x250
PK8c	8.5	3.12.1	ø125
PK9a	9.4	4.4	450x450
PK9b	9.4	4.4	450x450
PK10a	10.4	4.3	500x200
PK10b	10.4	4.3	500x200
PK12a	12.9	2.14	ø160
PK12b	12.9	4.4	ø160
PK12c	12.9	4.4	ø160
PK13a	13.5	4.3	180x180
PK14a	14.5	2.13	ø100

PK-požární klapka

1..10-číslo zařízení

a..d-pořadí

Provedení všech PK je se servopohonem 230VAC s koncovými stavy polohy listu klapky