

Architectural cross-section drawing of a building foundation and wall. The drawing shows a foundation with a sloped base and a vertical wall. Key dimensions include a total height of 3450, a wall height of 2800, and a foundation depth of 150. A door is shown in the wall with a height of 2200. Elevation markers include +3.650, +2.720, -0.680, and -1.030. A circular symbol with 'S' and '2' is located near the door, and a circular symbol with 'Z' and '2' is located near the top right corner.

Technical drawing showing a cross-section of a building foundation and ground level. The drawing includes the following dimensions and elevations:

- Overall width: 3450
- Foundation width: 2200
- Foundation height: 3200
- Foundation depth: 1000
- Foundation material: polštář hl. 1000
- Ground level elevation: +3.650
- Foundation elevation: 369.840
- Foundation bottom elevation: 368.860
- Foundation top elevation: 369.63
- Foundation bottom right elevation: 369.56
- Foundation bottom right elevation: 368.00
- Foundation bottom right elevation: 367.00
- Foundation bottom right elevation: 369.740
- Foundation bottom right elevation: 368.860
- Foundation bottom right elevation: 369.63
- Foundation bottom right elevation: 369.56
- Foundation bottom right elevation: 368.00
- Foundation bottom right elevation: 367.00

	KONSTRUKCE VS PREFABRIKOVANÁ BETONOVÁ BUŇKA
	ŠTERKOVÉ LOŽE
	ZÁSYP VYKOPANOU ZEMINOU
	NOVÁ BETONOVÁ DLAŽBA
	STÁVAJÍCÍ TERÉN

- | | |
|---|--|
|  | VENKOVNÍ ELOXOVANÉ DVEŘE
1000x1950 mm |
|  | OBNOVA CHODNÍKU Z BETONOVÉ DLAŽBY
BETONOVÁ DLAŽBA 60 mm
DRCENÉ KAMENIVO fr. 4 – 8 mm, tl. 30 mm
DRCENÉ KAMENIVO fr. 8 – 16 mm, tl. 110 mm |
|  | ŠTĚRKOVÉ LOŽE PRO OSAZENÍ BETONOVÉ BUŇKY
DRCENÉ KAMENIVO fr. 8 – 16 mm, tl. 50 mm
DRCENÉ KAMENIVO fr. 13 – 32 mm, tl. 100 mm |
|  | VĚTRACÍ OTVOR 200x200 mm, VE VÝŠCE 2120 mm
VĚTRACÍ PROTIDEŠŤOVÁ ŽALUZIE |

5	–	–	–
4	–	–	–
3	–	–	–
2	–	–	–
1	–	–	–
Číslo revize	Datum	Popis změny	Vypracoval

Z HOTOVITEL:

SITEZ

s.r.o.

Sídlíště Nová Ves – CPS
415 01 Teplice
www.sitez.cz

INVESTOR:

Severočeská teplárenská a.s.
Teplárenská 2
434 03 Most Komořany

Vyraboval			Zakázkové číslo	23 – 031
			Datum	03/2024
Kontroloval	Ing. Jan Mandzák		Stupeň	DPS
			Měřítka	1 : 50

Akce :

Rozšíření TN Litvínov etapa I.

D1–Dokumentace stavebních objektů

D1.1– HVS – stavební část

Obsah : ŘEZY	Poř. číslo : 04	Paré : 1
------------------------------------	---------------------------------------	--------------------------------