


Technical drawing of a ventilation system layout in a room. The drawing shows a network of ducts and components labeled with numbers 3.01 through 3.29. Key components include a SONODEC 500 1063 fan, a BS-650-350-150-150-90 duct, and various elbows and connectors. Dimensions and elevations are provided for various points. A note at the bottom states: "POTRUBÍ PŘIPOJIT NA POTRUBÍ VĚTRACÍHO STROPU DLE POŽADAVKŮ DODAVATELE" (Duct to be connected to the ceiling ventilation duct according to the requirements of the supplier).

ZÁVĚSY POTRUBÍ ZHOTOVIT PŘI MONTÁŽI
DLE POKYNŮ VED. MONTÉRA VZT

STŘECHA PŘÍSTAVKU

Technical drawing of a building floor plan showing the layout of a ventilation system. The plan includes rooms 3.01 and 3.21. A central ventilation unit is connected to various rooms via ducts. Labels include 'BFU 500 90', 'Ø500 300', 'PK Ø500', 'SLGU 500 900 100', and 'Ø500 200'. Arrows indicate the direction of airflow.

ARCHITEKTONICKÝ NÁVRH			
HIP ing. arch. K. Moudrý		GYMNASIOTIKA 2418/2, PRAHA 6 tel./fax: 283 89 15 70, E-mail: ofic@anita.cz	
ZOPOŘOVÝTEL FRANTI. KRATOCHVÍL	PROJEKTANT Č.čok. FRANTI. KRATOCHVÍL	DATUM 2/2014	ČÍSLO ZAKÁZKY 9 M 08
INVESTOR MZV ČR	STAVEBNÍ ÚŘAD	FORMÁT 16xA4	MĚŘÍTKO 1:50
NÁZEV AKCE REKONSTRUKCE KUCHYNĚ HOTELOVÉHO DOMU ČESKÝ DOM MOSKVA		STUPNĚNÍ DOKUMENTACE DPS	
ČÁST _____		PROFESE VLÝČKOTECHNIKA	
OBSAH MINUTKOVÁ KUCHYŇNĚ STROJ. VZT		ČÍSLO VÝČUKU VZ3/3	
		ČÍSLO TISKU	