

Performance of grid-connected PV

PVGIS-5 estimates of solar electricity generation:


Provided inputs:

Latitude/Longitude: 49.946,14.564
Horizon: Calculated
Database used: PVGIS-SARAH2
PV technology: Crystalline silicon
PV installed: 9.9 kWp
System loss: 14 %


Simulation outputs

Slope angle: 5 °
Azimuth angle: 35 °
Yearly PV energy production: 8974.26 kWh
Yearly in-plane irradiation: 1187.23 kWh/m²
Year-to-year variability: 362.07 kWh
Changes in output due to:
Angle of incidence: -4.09 %
Spectral effects: 1.54 %
Temperature and low irradiance: -8.84 %
Total loss: -23.65 %


Outline of horizon at chosen location:



Monthly energy output from fix-angle PV system:



Monthly in-plane irradiation for fixed-angle:



Monthly PV energy and solar irradiation

Month	E_m	H(i)_m	SD_m
January	224.3	29.1	37.0
February	382.8	47.7	67.8
March	695.5	87.9	93.3
April	1058.7	137.2	153.1
May	1198.8	157.6	153.1
June	1269.2	170.9	115.7
July	1273.0	174.1	123.3
August	1106.5	150.1	88.0
September	818.7	107.9	92.6
October	513.6	66.9	84.8
November	248.3	32.9	33.6
December	184.8	25.0	20.7

E_m: Average monthly electricity production from the defined system [kWh].

H(i)_m: Average monthly sum of global irradiation per square meter received by the modules of the given system [kWh/m²].

SD_m: Standard deviation of the monthly electricity production due to year-to-year variation [kWh].